


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

**System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: January 2023**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	0.34	N/A	N/A	N/A	0.34
7	N/A	N/A	0.48	N/A	N/A	N/A	0.48
8	N/A	N/A	0.41	N/A	N/A	N/A	0.41
9	N/A	N/A	0.45	N/A	N/A	N/A	0.45
10	N/A	N/A	0.46	N/A	N/A	N/A	0.46
11	N/A	N/A	0.41	N/A	N/A	N/A	0.41
12	N/A	N/A	0.30	N/A	N/A	N/A	0.30
13	N/A	N/A	0.43	N/A	N/A	N/A	0.43
14	N/A	N/A	0.33	N/A	N/A	N/A	0.33
15	N/A	N/A	0.37	N/A	N/A	N/A	0.37
16	N/A	N/A	0.41	N/A	N/A	N/A	0.41
17	N/A	N/A	0.40	N/A	N/A	N/A	0.40
18	N/A	N/A	0.38	N/A	N/A	N/A	0.38
19	N/A	N/A	0.34	N/A	N/A	N/A	0.34
20	N/A	N/A	0.32	N/A	N/A	N/A	0.32
21	N/A	N/A	0.25	N/A	N/A	N/A	0.25
22	N/A	N/A	0.24	N/A	N/A	N/A	0.24
23	N/A	N/A	0.24	N/A	N/A	N/A	0.24
24	N/A	N/A	0.20	N/A	N/A	N/A	0.20
25	N/A	N/A	0.20	N/A	N/A	N/A	0.20
26	N/A	N/A	0.23	N/A	N/A	N/A	0.23
27	N/A	N/A	0.20	N/A	N/A	N/A	0.20
28	N/A	N/A	0.19	N/A	N/A	N/A	0.19
29	N/A	N/A	0.18	N/A	N/A	N/A	0.18
30	N/A	N/A	0.15	N/A	N/A	N/A	0.15
31	N/A	N/A	0.15	N/A	N/A	N/A	0.15

<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>	<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
All daily readings ≤ 5 NTU? <b>YES</b>	<b>PRINTED NAME: Joe Rogers</b>	
<b>Notes:</b>	<b>SIGNATURE</b> 	<b>DATE 2/01/2023</b>
	<b>PHONE #: (503) -723-3505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: January 2023**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
01/01/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/02/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/03/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/04/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/05/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/06/23	6:00 AM	1.5	111	169	6.7	7.9	68	Yes	2735
01/07/23	6:00 AM	1.5	95	147	6.3	7.8	67	Yes	3263
01/08/23	6:00 AM	1.6	94	149	6.1	7.8	68	Yes	3422
01/09/23	6:00 AM	1.5	94	142	6.5	7.7	63	Yes	3297
01/10/23	6:00 AM	1.5	98	148	6.7	7.8	65	Yes	3236
01/11/23	6:00 AM	1.5	101	151	6.5	7.8	66	Yes	3142
01/12/23	6:00 AM	1.5	83	123	6.8	7.9	67	Yes	3670
01/13/23	6:00 AM	1.5	99	144	7.1	7.9	66	Yes	3228
01/14/23	6:00 AM	1.5	99	149	7.1	7.8	64	Yes	3220
01/15/23	6:00 AM	1.5	90	135	6.9	8.0	69	Yes	3245
01/16/23	6:00 AM	1.5	103	150	7.1	7.8	63	Yes	3141
01/17/23	6:00 AM	1.5	101	147	7.1	7.9	66	Yes	3160
01/18/23	6:00 AM	1.5	86	130	7.1	7.8	64	Yes	3580
01/19/23	6:00 AM	1.6	98	154	6.9	7.8	65	Yes	3288
01/20/23	6:00 AM	1.5	95	142	6.5	7.9	68	Yes	3380
01/21/23	6:00 AM	1.4	105	147	6.2	7.9	69	Yes	2967
01/22/23	6:00 AM	1.5	102	150	5.9	7.8	68	Yes	3109
01/23/23	6:00 AM	1.4	101	145	6.0	7.8	67	Yes	3023
01/24/23	6:00 AM	1.5	119	172	6.0	7.6	62	Yes	2623
01/25/23	6:00 AM	1.6	93	144	5.8	8.1	77	Yes	3361
01/26/23	6:00 AM	1.6	90	141	5.8	7.9	72	Yes	3495
01/27/23	6:00 AM	1.5	106	160	6.1	7.9	70	Yes	2984
01/28/23	6:00 AM	1.5	104	156	6.4	7.9	69	Yes	2935
01/29/23	6:00 AM	1.5	108	161	5.8	7.8	68	Yes	2920
01/30/23	6:00 AM	1.4	123	172	4.6	7.8	73	Yes	2475
01/31/23	6:00AM	1.4	127	180	4.3	7.9	78	Yes	2369

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day