


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: February 2023							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.13	N/A	N/A	N/A	0.13
2	N/A	N/A	0.17	N/A	N/A	N/A	0.17
3	N/A	N/A	0.20	N/A	N/A	N/A	0.20
4	N/A	N/A	0.27	N/A	N/A	N/A	0.27
5	N/A	N/A	0.21	N/A	N/A	N/A	0.21
6	N/A	N/A	0.27	N/A	N/A	N/A	0.27
7	N/A	N/A	0.25	N/A	N/A	N/A	0.25
8	N/A	N/A	0.24	N/A	N/A	N/A	0.24
9	N/A	N/A	0.30	N/A	N/A	N/A	0.30
10	N/A	N/A	0.27	N/A	N/A	N/A	0.27
11	N/A	N/A	0.24	N/A	N/A	N/A	0.24
12	N/A	N/A	0.24	N/A	N/A	N/A	0.24
13	N/A	N/A	0.26	N/A	N/A	N/A	0.26
14	N/A	N/A	0.20	N/A	N/A	N/A	0.20
15	N/A	N/A	0.21	N/A	N/A	N/A	0.21
16	N/A	N/A	0.19	N/A	N/A	N/A	0.19
17	N/A	N/A	0.17	N/A	N/A	N/A	0.17
18	N/A	N/A	0.14	N/A	N/A	N/A	0.14
19	N/A	N/A	0.14	N/A	N/A	N/A	0.14
20	N/A	N/A	0.12	N/A	N/A	N/A	0.12
21	N/A	N/A	0.15	N/A	N/A	N/A	0.15
22	N/A	N/A	0.15	N/A	N/A	N/A	0.15
23	N/A	N/A	0.15	N/A	N/A	N/A	0.15
24	N/A	N/A	0.17	N/A	N/A	N/A	0.17
25	N/A	N/A	0.14	N/A	N/A	N/A	0.14
26	N/A	N/A	0.13	N/A	N/A	N/A	0.13
27	N/A	N/A	0.15	N/A	N/A	N/A	0.15
28	N/A	N/A	0.18	N/A	N/A	N/A	0.18
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES							
Notes:				PRINTED NAME: Joe Rogers			
				SIGNATURE 		DATE 3/01/2023	
				PHONE #: (503) 223-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: February 2023

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
02/01/23	6:00 AM	1.5	114	171	4.3	8.0	82	Yes	2604
02/02/23	6:00 AM	1.5	93	142	4.5	8.0	81	Yes	3403
02/03/23	6:00 AM	1.4	96	138	4.4	7.8	75	Yes	3365
02/04/23	6:00 AM	1.4	103	148	4.5	7.9	77	Yes	2953
02/05/23	6:00 AM	1.4	103	142	4.8	7.7	69	Yes	2975
02/06/23	6:00 AM	1.4	119	166	5.2	8.2	82	Yes	2557
02/07/23	6:00 AM	1.5	123	185	5.5	8.2	81	Yes	2557
02/08/23	6:00 AM	1.5	90	137	5.8	7.9	71	Yes	3389
02/09/23	6:00 AM	1.5	92	137	6.1	7.8	67	Yes	3556
02/10/23	6:00 AM	1.5	91	137	6.2	7.8	67	Yes	3568
02/11/23	6:00 AM	1.5	92	137	6.8	7.9	67	Yes	3481
02/12/23	6:00 AM	1.5	106	159	6.5	7.7	63	Yes	2934
02/13/23	6:00 AM	1.5	107	160	6.1	8.1	76	Yes	2847
02/14/23	6:00 AM	1.5	106	160	6.0	7.7	65	Yes	2926
02/15/23	6:00 AM	1.6	92	146	5.9	7.8	69	Yes	3441
02/16/23	6:00 AM	1.6	96	154	5.8	7.8	69	Yes	3162
02/17/23	6:00 AM	1.6	95	152	5.6	7.7	67	Yes	3382
02/18/23	6:00 AM	1.5	96	144	6.2	7.9	70	Yes	3346
02/19/23	6:00 AM	1.5	96	145	6.9	7.9	67	Yes	3340
02/20/23	6:00 AM	1.5	96	144	6.5	7.9	68	Yes	3349
02/21/23	6:00 AM	1.5	95	142	6.8	7.9	67	Yes	3393
02/22/23	6:00 AM	1.5	92	138	6.2	7.8	67	Yes	3499
02/23/23	6:00 AM	1.5	86	130	4.2	7.9	80	Yes	3811
02/24/23	6:00 AM	1.5	86	129	3.7	7.8	80	Yes	3660
02/25/23	6:00 AM	1.5	88	132	4.0	7.9	81	Yes	3691
02/26/23	6:00 AM	1.6	101	165	4.2	7.6	72	Yes	3149
02/27/23	6:00 AM	1.5	100	150	4.2	7.7	74	Yes	3116
02/28/23	6:00 AM	1.4	101	142	4.2	7.8	76	Yes	3141

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day