


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: March 2023							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.14	N/A	N/A	N/A	0.14
2	N/A	N/A	0.25	N/A	N/A	N/A	0.25
3	N/A	N/A	0.22	N/A	N/A	N/A	0.22
4	N/A	N/A	0.20	N/A	N/A	N/A	0.20
5	N/A	N/A	0.20	N/A	N/A	N/A	0.20
6	N/A	N/A	0.26	N/A	N/A	N/A	0.26
7	N/A	N/A	0.23	N/A	N/A	N/A	0.23
8	N/A	N/A	0.26	N/A	N/A	N/A	0.26
9	N/A	N/A	0.23	N/A	N/A	N/A	0.23
10	N/A	N/A	0.29	N/A	N/A	N/A	0.29
11	N/A	N/A	0.19	N/A	N/A	N/A	0.19
12	N/A	N/A	0.16	N/A	N/A	N/A	0.16
13	N/A	N/A	0.16	N/A	N/A	N/A	0.16
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
16	N/A	N/A	0.28	N/A	N/A	N/A	0.28
17	N/A	N/A	0.23	N/A	N/A	N/A	0.23
18	N/A	N/A	0.25	N/A	N/A	N/A	0.25
19	N/A	N/A	0.24	N/A	N/A	N/A	0.24
20	N/A	N/A	0.16	N/A	N/A	N/A	0.16
21	N/A	N/A	0.15	N/A	N/A	N/A	0.15
22	N/A	N/A	0.14	N/A	N/A	N/A	0.14
23	N/A	N/A	0.18	N/A	N/A	N/A	0.18
24	N/A	N/A	0.11	N/A	N/A	N/A	0.11
25	N/A	N/A	0.13	N/A	N/A	N/A	0.13
26	N/A	N/A	0.13	N/A	N/A	N/A	0.13
27	N/A	N/A	0.13	N/A	N/A	N/A	0.13
28	N/A	N/A	0.12	N/A	N/A	N/A	0.12
29	N/A	N/A	0.12	N/A	N/A	N/A	0.12
30	N/A	N/A	0.14	N/A	N/A	N/A	0.14
31	N/A	N/A	0.17	N/A	N/A	N/A	0.17
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE 4/01/2023	
				PHONE #: (503) -723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: March 2023

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
03/01/23	6:00 AM	1.5	158	232	4.6	8.2	86	Yes	1930
03/02/23	6:00 AM	1.5	88	128	5.0	8.0	77	Yes	3378
03/03/23	6:00 AM	1.5	141	205	5.0	7.9	74	Yes	2181
03/04/23	6:00 AM	1.5	124	185	5.4	8.0	75	Yes	2395
03/05/23	6:00 AM	1.4	137	196	5.4	7.9	72	Yes	2268
03/06/23	6:00 AM	1.5	133	197	5.1	7.8	71	Yes	2257
03/07/23	6:00 AM	1.5	149	225	5.2	7.9	74	Yes	2045
03/08/23	6:00 AM	1.4	175	241	6.0	7.8	67	Yes	1721
03/09/23	6:00 AM	1.4	170	245	5.8	7.9	71	Yes	1748
03/10/23	6:00 AM	1.5	143	215	5.9	7.8	68	Yes	2096
03/11/23	6:00 AM	1.4	172	243	6.2	7.7	63	Yes	1743
03/12/23	6:00 AM	1.4	183	252	6.2	7.8	66	Yes	1665
03/13/23	6:00 AM	1.4	180	253	6.2	7.8	66	Yes	1705
03/14/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/15/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/16/23	6:00 AM	1.5	137	199	7.1	7.8	63	Yes	2164
03/17/23	6:00 AM	1.5	140	205	6.4	8.0	71	Yes	2142
03/18/23	6:00 AM	1.5	139	206	7.0	7.9	66	Yes	2169
03/19/23	6:00 AM	1.5	154	226	8.1	8.0	64	Yes	1904
03/20/23	6:00 AM	1.4	167	236	7.4	8.1	69	Yes	1795
03/21/23	6:00 AM	1.4	174	235	7.5	8.0	66	Yes	1706
03/22/23	6:00 AM	1.2	355	427	7.7	7.9	62	Yes	835
03/23/23	6:00 AM	1.1	192	211	7.8	8.0	63	Yes	1605
03/24/23	6:00 AM	1.2	320	374	7.7	7.9	62	Yes	916
03/25/23	6:00 AM	1.8	115	208	6.8	7.9	70	Yes	2540
03/26/23	6:00 AM	1.3	169	220	7.2	7.8	62	Yes	1774
03/27/23	6:00 AM	1.4	172	232	7.5	7.7	59	Yes	1750
03/28/23	6:00 AM	1.4	173	233	7.2	7.8	62	Yes	1741
03/29/23	6:00 AM	1.3	197	262	6.9	7.7	61	Yes	1470
03/30/23	6:00 AM	1.7	128	211	7.2	7.7	62	Yes	2294
03/31/23	6:00AM	1.3	187	246	7.7	7.5	53	Yes	1603

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day