


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: May 2023								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
2	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
3	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
4	N/A	N/A	0.21	N/A	N/A	N/A	0.21	
5	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
6	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
7	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
8	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
9	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
10	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
11	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
12	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
13	N/A	N/A	0.21	N/A	N/A	N/A	0.21	
14	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
15	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
16	N/A	N/A	0.27	N/A	N/A	N/A	0.27	
17	N/A	N/A	0.27	N/A	N/A	N/A	0.27	
18	N/A	N/A	0.25	N/A	N/A	N/A	0.25	
19	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
20	N/A	N/A	0.22	N/A	N/A	N/A	0.22	
21	N/A	N/A	0.19	N/A	N/A	N/A	0.19	
22	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
23	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
24	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
25	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
26	N/A	N/A	0.12	N/A	N/A	N/A	0.12	
27	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
28	N/A	N/A	0.20	N/A	N/A	N/A	0.20	
29	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
30	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
31	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings \leq 1 NTU? YES All daily readings \leq 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 6/01/2023	
				PHONE #: (503) 23-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: May 2023

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
05/01/23	6:00 AM	1.5	131	194	10.0	7.7	51	Yes	2231
05/02/23	6:00 AM	1.4	138	191	9.1	7.8	55	Yes	2183
05/03/23	6:00 AM	1.5	123	182	10.0	7.8	53	Yes	2353
05/04/23	6:00 AM	1.8	73	132	10.2	7.9	57	Yes	4155
05/05/23	6:00 AM	1.5	125	184	9.2	7.9	58	Yes	2423
05/06/23	6:00 AM	1.4	135	183	9.5	7.7	52	Yes	2165
05/07/23	6:00 AM	1.4	137	189	9.7	7.7	51	Yes	2169
05/08/23	6:00 AM	1.5	140	208	10.0	7.8	53	Yes	2178
05/09/23	6:00 AM	1.4	137	189	10.1	7.8	52	Yes	2195
05/10/23	6:00 AM	1.4	144	196	10.7	7.8	50	Yes	2109
05/11/23	6:00 AM	1.6	82	128	11.1	7.9	51	Yes	3740
05/12/23	6:00 AM	1.6	79	124	12.0	7.7	45	Yes	3981
05/13/23	6:00 AM	1.7	71	123	12.0	7.6	44	Yes	4469
05/14/23	6:00 AM	1.5	66	99	12.2	7.8	45	Yes	4661
05/15/23	6:00 AM	1.4	75	101	12.8	7.7	41	Yes	4418
05/16/23	6:00 AM	1.3	73	96	12.8	7.9	44	Yes	4471
05/17/23	6:00 AM	1.4	71	97	12.8	7.7	41	Yes	4260
05/18/23	6:00 AM	1.4	63	86	13.0	7.7	41	Yes	5285
05/19/23	6:00 AM	1.5	63	93	13.7	7.7	39	Yes	5632
05/20/23	6:00 AM	1.4	65	90	13.8	7.8	40	Yes	5507
05/21/23	6:00 AM	1.5	87	129	13.9	7.8	39	Yes	3680
05/22/23	6:00 AM	1.3	91	121	12.4	7.9	46	Yes	3448
05/23/23	6:00 AM	1.3	95	126	12.4	7.9	46	Yes	3252
05/24/23	6:00 AM	1.6	109	172	12.2	7.7	44	Yes	2815
05/25/23	6:00 AM	1.4	90	129	13.2	7.7	40	Yes	3485
05/26/23	6:00 AM	1.4	84	121	13.9	7.7	38	Yes	3523
05/27/23	6:00 AM	1.5	70	104	14.3	7.7	37	Yes	4825
05/28/23	6:00 AM	1.5	69	101	14.5	7.8	37	Yes	4983
05/29/23	6:00 AM	1.5	70	102	14.0	7.7	38	Yes	5101
05/30/23	6:00 AM	1.4	70	97	14.6	7.7	36	Yes	5091
05/31/23	6:00AM	1.4	58	82	14.5	7.8	37	Yes	5388

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day