


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: July 2023							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.09	N/A	N/A	N/A	0.09
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.09	N/A	N/A	N/A	0.09
7	N/A	N/A	0.11	N/A	N/A	N/A	0.11
8	N/A	N/A	0.12	N/A	N/A	N/A	0.12
9	N/A	N/A	0.12	N/A	N/A	N/A	0.12
10	N/A	N/A	0.12	N/A	N/A	N/A	0.12
11	N/A	N/A	0.12	N/A	N/A	N/A	0.12
12	N/A	N/A	0.15	N/A	N/A	N/A	0.15
13	N/A	N/A	0.11	N/A	N/A	N/A	0.11
14	N/A	N/A	0.13	N/A	N/A	N/A	0.13
15	N/A	N/A	0.10	N/A	N/A	N/A	0.10
16	N/A	N/A	0.11	N/A	N/A	N/A	0.11
17	N/A	N/A	0.11	N/A	N/A	N/A	0.11
18	N/A	N/A	0.09	N/A	N/A	N/A	0.09
19	N/A	N/A	0.11	N/A	N/A	N/A	0.11
20	N/A	N/A	0.10	N/A	N/A	N/A	0.10
21	N/A	N/A	0.10	N/A	N/A	N/A	0.10
22	N/A	N/A	0.08	N/A	N/A	N/A	0.08
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09
25	N/A	N/A	0.12	N/A	N/A	N/A	0.12
26	N/A	N/A	0.11	N/A	N/A	N/A	0.11
27	N/A	N/A	0.09	N/A	N/A	N/A	0.09
28	N/A	N/A	0.09	N/A	N/A	N/A	0.09
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES							
Notes:				PRINTED NAME: Joe Rogers			
				SIGNATURE 		DATE 8/01/2023	
				PHONE #: (503) 723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-BI Month/Year: July 2023

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
07/01/23	6:00 AM	1.5	59	85	21.0	7.6	23	Yes	6660
07/02/23	6:00 AM	1.4	58	78	20.5	7.8	26	Yes	6500
07/03/23	6:00 AM	1.4	60	81	21.0	7.7	24	Yes	5999
07/04/23	6:00 AM	1.3	68	89	20.8	7.6	23	Yes	5408
07/05/23	6:00 AM	1.3	67	88	21.2	7.7	24	Yes	4755
07/06/23	6:00 AM	1.4	61	88	20.9	7.5	23	Yes	6078
07/07/23	6:00 AM	1.4	60	81	21.5	7.5	22	Yes	6395
07/08/23	6:00 AM	1.3	60	79	21.3	7.6	23	Yes	6349
07/09/23	6:00 AM	1.3	60	78	20.5	7.6	24	Yes	6406
07/10/23	6:00 AM	1.3	60	77	20.3	7.6	24	Yes	6418
07/11/23	6:00 AM	1.4	60	83	19.7	7.6	25	Yes	6410
07/12/23	6:00 AM	1.4	61	85	21.7	7.6	22	Yes	6334
07/13/23	6:00 AM	1.4	59	81	20.9	7.6	23	Yes	6469
07/14/23	6:00 AM	1.4	60	81	22.2	7.5	20	Yes	6411
07/15/23	6:00 AM	1.3	60	80	22.7	7.6	20	Yes	6362
07/16/23	6:00 AM	1.3	60	78	22.8	7.6	20	Yes	6370
07/17/23	6:00 AM	1.3	60	77	22.8	7.6	20	Yes	6317
07/18/23	6:00 AM	1.3	55	72	21.1	7.6	23	Yes	6215
07/19/23	6:00 AM	1.3	67	87	21.9	7.5	21	Yes	4723
07/20/23	6:00 AM	1.3	60	80	22.4	7.5	20	Yes	5610
07/21/23	6:00 AM	1.4	63	85	22.8	7.6	20	Yes	4907
07/22/23	6:00 AM	1.3	62	83	23.0	7.6	20	Yes	5624
07/23/23	6:00 AM	1.4	59	82	23.1	7.6	20	Yes	6350
07/24/23	6:00 AM	1.2	60	74	22.6	7.6	20	Yes	6391
07/25/23	6:00 AM	1.3	56	71	21.0	7.7	24	Yes	6195
07/26/23	6:00 AM	1.3	63	82	21.2	7.7	24	Yes	5140
07/27/23	6:00 AM	1.3	60	77	21.8	7.7	23	Yes	6044
07/28/23	6:00 AM	1.3	59	76	21.9	7.6	22	Yes	6413
07/29/23	6:00 AM	1.3	58	74	21.9	7.7	22	Yes	6745
07/30/23	6:00 AM	1.3	59	73	21.2	7.7	24	Yes	6739
07/31/23	6:00AM	1.3	55	72	21.6	7.7	23	Yes	6327

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day