

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

**System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: August 2023**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.10	N/A	N/A	N/A	0.10
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08
5	N/A	N/A	0.08	N/A	N/A	N/A	0.08
6	N/A	N/A	0.09	N/A	N/A	N/A	0.09
7	N/A	N/A	0.09	N/A	N/A	N/A	0.09
8	N/A	N/A	0.10	N/A	N/A	N/A	0.10
9	N/A	N/A	0.08	N/A	N/A	N/A	0.08
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07
12	N/A	N/A	0.09	N/A	N/A	N/A	0.09
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.08	N/A	N/A	N/A	0.08
15	N/A	N/A	0.08	N/A	N/A	N/A	0.08
16	N/A	N/A	0.07	N/A	N/A	N/A	0.07
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09
18	N/A	N/A	0.07	N/A	N/A	N/A	0.07
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.14	N/A	N/A	N/A	0.14
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.08	N/A	N/A	N/A	0.08
23	N/A	N/A	0.10	N/A	N/A	N/A	0.10
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.15	N/A	N/A	N/A	0.15
28	N/A	N/A	0.12	N/A	N/A	N/A	0.12
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.10	N/A	N/A	N/A	0.10
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08

<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>	<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b> All daily readings ≤ 5 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
<b>Notes:</b>	<b>PRINTED NAME: Joe Rogers</b>	
	<b>SIGNATURE</b>	<b>DATE 9/01/2023</b>
	<b>PHONE #: (503) -723-3505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: August 2023**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
08/01/23	6:00 AM	1.4	52	71	21.7	7.6	22	Yes	5179
08/02/23	6:00 AM	1.4	59	80	21.5	7.7	23	Yes	5839
08/03/23	6:00 AM	1.3	62	78	21.9	7.6	22	Yes	5955
08/04/23	6:00 AM	1.3	63	79	22.2	7.6	21	Yes	5888
08/05/23	6:00 AM	1.2	64	79	21.2	7.7	24	Yes	5815
08/06/23	6:00 AM	1.2	64	78	19.4	7.7	27	Yes	5798
08/07/23	6:00 AM	1.3	63	80	20.8	7.6	23	Yes	5831
08/08/23	6:00 AM	1.3	63	79	21.5	7.6	22	Yes	5857
08/09/23	6:00 AM	1.3	63	80	21.8	7.6	22	Yes	5813
08/10/23	6:00 AM	1.3	64	80	21.9	7.7	22	Yes	5808
08/11/23	6:00 AM	1.3	63	79	21.8	7.7	23	Yes	5789
08/12/23	6:00 AM	1.2	62	77	21.8	7.6	22	Yes	5969
08/13/23	6:00 AM	1.2	63	76	22.0	7.6	21	Yes	5908
08/14/23	6:00 AM	1.4	56	77	22.7	7.7	21	Yes	5977
08/15/23	6:00 AM	1.3	61	77	23.2	7.7	20	Yes	5441
08/16/23	6:00 AM	1.3	58	74	23.2	7.8	21	Yes	6016
08/17/23	6:00 AM	1.3	60	77	23.9	7.6	18	Yes	6283
08/18/23	6:00 AM	1.2	64	80	21.9	7.6	22	Yes	5743
08/19/23	6:00 AM	1.2	62	76	21.5	7.7	23	Yes	5895
08/20/23	6:00 AM	1.2	64	76	20.4	7.6	24	Yes	5635
08/21/23	6:00 AM	1.3	62	79	20.3	7.8	26	Yes	5482
08/22/23	6:00 AM	1.3	71	88	20.2	7.7	25	Yes	4555
08/23/23	6:00 AM	1.3	63	78	19.8	7.6	25	Yes	5611
08/24/23	6:00 AM	1.2	63	78	19.8	7.7	26	Yes	5830
08/25/23	6:00 AM	1.3	63	81	20.1	7.7	25	Yes	6276
08/26/23	6:00 AM	1.3	59	75	21.7	7.7	23	Yes	6273
08/27/23	6:00 AM	1.3	67	85	22.1	7.6	21	Yes	4739
08/28/23	6:00 AM	1.3	64	83	22.0	7.7	22	Yes	5338
08/29/23	6:00 AM	1.3	67	86	19.4	7.8	27	Yes	5325
08/30/23	6:00 AM	1.3	69	93	19.1	7.8	28	Yes	5230
08/31/23	6:00AM	1.2	75	88	19.8	7.7	26	Yes	4808

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day