


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: September 2023							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.07	N/A	N/A	N/A	0.07
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.09	N/A	N/A	N/A	0.09
5	N/A	N/A	0.13	N/A	N/A	N/A	0.13
6	N/A	N/A	0.08	N/A	N/A	N/A	0.08
7	N/A	N/A	0.09	N/A	N/A	N/A	0.09
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09
10	N/A	N/A	0.10	N/A	N/A	N/A	0.10
11	N/A	N/A	0.11	N/A	N/A	N/A	0.11
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.08	N/A	N/A	N/A	0.08
14	N/A	N/A	0.08	N/A	N/A	N/A	0.08
15	N/A	N/A	0.11	N/A	N/A	N/A	0.11
16	N/A	N/A	0.07	N/A	N/A	N/A	0.07
17	N/A	N/A	0.10	N/A	N/A	N/A	0.10
18	N/A	N/A	0.07	N/A	N/A	N/A	0.07
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.05	N/A	N/A	N/A	0.05
22	N/A	N/A	0.06	N/A	N/A	N/A	0.06
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.07	N/A	N/A	N/A	0.07
25	N/A	N/A	0.09	N/A	N/A	N/A	0.09
26	N/A	N/A	0.12	N/A	N/A	N/A	0.12
27	N/A	N/A	0.18	N/A	N/A	N/A	0.18
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.06	N/A	N/A	N/A	0.06
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES							
Notes:				PRINTED NAME: Joe Rogers			
				SIGNATURE 		DATE 10/01/2023	
				PHONE #: (503) 723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: September 2023

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
09/01/23	6:00 AM	1.2	73	84	18.4	7.7	28	Yes	4764
09/02/23	6:00 AM	1.1	72	82	19.5	7.7	26	Yes	4757
09/03/23	6:00 AM	1.1	70	79	20.5	7.8	25	Yes	4903
09/04/23	6:00 AM	1.1	111	121	18.4	8.1	32	Yes	2780
09/05/23	6:00 AM	1.3	78	99	17.5	7.9	32	Yes	4303
09/06/23	6:00 AM	1.2	79	94	18.3	8.0	31	Yes	4070
09/07/23	6:00 AM	1.3	61	80	18.8	7.8	29	Yes	5362
09/08/23	6:00 AM	1.3	67	86	18.4	7.7	28	Yes	5277
09/09/23	6:00 AM	1.3	66	85	18.3	7.8	29	Yes	5357
09/10/23	6:00 AM	1.4	51	73	18.3	7.8	30	Yes	5423
09/11/23	6:00 AM	1.2	73	88	18.3	7.7	28	Yes	4735
09/12/23	6:00 AM	1.2	66	79	18.2	7.9	30	Yes	4927
09/13/23	6:00 AM	1.2	83	96	19.2	7.8	28	Yes	3655
09/14/23	6:00 AM	1.3	69	89	18.6	7.8	29	Yes	4777
09/15/23	6:00 AM	1.2	70	86	18.5	7.8	29	Yes	4971
09/16/23	6:00 AM	1.3	69	90	18.6	7.6	27	Yes	5053
09/17/23	6:00 AM	1.2	69	85	18.4	7.9	30	Yes	5061
09/18/23	6:00 AM	1.2	75	86	17.8	7.8	30	Yes	4553
09/19/23	6:00 AM	1.3	77	103	17.1	7.8	32	Yes	4160
09/20/23	6:00 AM	1.3	75	99	16.9	7.9	33	Yes	4389
09/21/23	6:00 AM	1.3	76	97	16.2	7.8	33	Yes	4060
09/22/23	6:00 AM	1.4	62	84	16.2	7.8	33	Yes	5708
09/23/23	6:00 AM	1.3	58	77	16.3	7.8	33	Yes	5706
09/24/23	6:00 AM	1.4	77	105	15.5	7.9	36	Yes	4257
09/25/23	6:00 AM	1.3	73	92	16.7	7.8	32	Yes	4191
09/26/23	6:00 AM	1.3	79	101	14.6	7.6	34	Yes	4188
09/27/23	6:00 AM	1.4	84	116	17.1	7.7	31	Yes	3982
09/28/23	6:00 AM	1.4	84	115	15.0	7.7	34	Yes	3984
09/29/23	6:00 AM	1.4	85	116	14.9	7.7	35	Yes	4002
09/30/23	6:00 AM	1.3	85	114	14.4	7.7	36	Yes	3982

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day