


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: October 2023								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
3	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
7	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
10	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
11	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
12	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
14	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
15	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
16	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
17	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
18	N/A	N/A	0.11	N/A	N/A	N/A	0.11	
19	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
20	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
21	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
22	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
23	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
26	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
27	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
30	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 11/01/2023	
				PHONE #: (503) -723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: October 2023

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
10/01/23	6:00 AM	1.4	85	118	14.3	7.7	36	Yes	3991
10/02/23	6:00 AM	1.3	80	106	14.0	7.8	39	Yes	4007
10/03/23	6:00 AM	1.4	80	115	13.9	7.8	39	Yes	4289
10/04/23	6:00 AM	1.3	82	108	14.1	7.8	38	Yes	4217
10/05/23	6:00 AM	1.4	81	110	14.2	7.6	35	Yes	4248
10/06/23	6:00 AM	1.4	81	109	14.9	7.6	33	Yes	4169
10/07/23	6:00 AM	1.3	85	110	15.4	7.7	33	Yes	3968
10/08/23	6:00 AM	1.4	69	95	15.3	7.6	32	Yes	4355
10/09/23	6:00 AM	1.4	81	113	15.4	7.7	34	Yes	4264
10/10/23	6:00 AM	1.3	81	107	14.2	7.7	36	Yes	4216
10/11/23	6:00 AM	1.3	77	99	13.9	7.7	37	Yes	4083
10/12/23	6:00 AM	1.3	115	144	14.1	7.6	35	Yes	2765
10/13/23	6:00 AM	1.4	106	148	14.2	7.6	36	Yes	2813
10/14/23	6:00 AM	1.3	105	137	13.8	7.6	36	Yes	2989
10/15/23	6:00 AM	1.2	109	134	13.4	7.7	39	Yes	2949
10/16/23	6:00 AM	1.2	104	129	14.1	7.7	36	Yes	2845
10/17/23	6:00 AM	1.3	95	119	13.7	7.7	38	Yes	3261
10/18/23	6:00 AM	1.3	91	122	13.5	7.7	39	Yes	3129
10/19/23	6:00 AM	1.4	94	130	13.2	7.6	38	Yes	3317
10/20/23	6:00 AM	1.3	95	128	13.4	7.6	38	Yes	3375
10/21/23	6:00 AM	1.4	97	131	13.4	7.6	38	Yes	3320
10/22/23	6:00 AM	1.4	85	116	13.1	7.7	40	Yes	3384
10/23/23	6:00 AM	1.4	82	114	12.9	7.6	39	Yes	3525
10/24/23	6:00 AM	1.3	93	122	12.5	7.7	42	Yes	3555
10/25/23	6:00 AM	1.3	84	111	11.8	7.8	46	Yes	3529
10/26/23	6:00 AM	1.4	99	139	11.3	7.7	46	Yes	3229
10/27/23	6:00 AM	1.4	99	137	11.1	7.6	45	Yes	3260
10/28/23	6:00 AM	1.4	100	138	10.6	7.7	48	Yes	3198
10/29/23	6:00 AM	1.4	96	133	9.1	7.7	53	Yes	3194
10/30/23	6:00 AM	1.3	122	157	8.7	8.3	68	Yes	2571
10/31/23	6:00AM	1.3	112	142	9.1	7.8	55	Yes	2738

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day