


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

**System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:-: WTP-B1 Month/Year: November 2023**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.11	N/A	N/A	N/A	0.11
2	N/A	N/A	0.11	N/A	N/A	N/A	0.11
3	N/A	N/A	0.07	N/A	N/A	N/A	0.07
4	N/A	N/A	0.13	N/A	N/A	N/A	0.13
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
9	N/A	N/A	0.16	N/A	N/A	N/A	0.16
10	N/A	N/A	0.14	N/A	N/A	N/A	0.14
11	N/A	N/A	0.12	N/A	N/A	N/A	0.12
12	N/A	N/A	0.12	N/A	N/A	N/A	0.12
13	N/A	N/A	0.09	N/A	N/A	N/A	0.09
14	N/A	N/A	0.10	N/A	N/A	N/A	0.10
15	N/A	N/A	0.07	N/A	N/A	N/A	0.07
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09
18	N/A	N/A	0.09	N/A	N/A	N/A	0.09
19	N/A	N/A	0.12	N/A	N/A	N/A	0.12
20	N/A	N/A	0.08	N/A	N/A	N/A	0.08
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.09	N/A	N/A	N/A	0.09
26	N/A	N/A	0.09	N/A	N/A	N/A	0.09
27	N/A	N/A	0.09	N/A	N/A	N/A	0.09
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.06	N/A	N/A	N/A	0.06

<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>	<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? YES	CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES		
<b>Notes:</b>	<b>PRINTED NAME: Joe Rogers</b>	
	<b>SIGNATURE</b> 	<b>DATE 12/01/2023</b>
	<b>PHONE #: (503) -423-8505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: November 2023**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT (C x T)	Temp (°C)	pH	Required CT (Use Tables)	CT Met?*	Peak Hourly Demand Flow (gpm)
11/01/23	6:00 AM	1.4	86	121	8.5	7.8	58	Yes	3672
11/02/23	6:00 AM	1.4	88	122	9.2	7.7	53	Yes	3775
11/03/23	6:00 AM	1.3	90	117	10.1	7.7	50	Yes	3712
11/04/23	6:00 AM	1.4	102	147	9.9	7.7	51	Yes	3012
11/05/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/06/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/07/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/08/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/09/23	6:00 AM	1.2	125	149	10.6	7.5	44	Yes	2371
11/10/23	6:00 AM	1.4	97	132	9.6	7.6	49	Yes	3121
11/11/23	6:00 AM	1.4	101	145	9.3	7.6	51	Yes	3174
11/12/23	6:00 AM	1.5	94	138	9.1	7.9	58	Yes	3288
11/13/23	6:00 AM	1.4	131	177	9.2	7.8	55	Yes	2368
11/14/23	6:00 AM	1.3	128	171	9.1	7.6	51	Yes	2343
11/15/23	6:00 AM	1.5	94	142	9.1	7.6	52	Yes	3228
11/16/23	6:00 AM	1.4	94	134	9.1	7.6	51	Yes	3358
11/17/23	6:00 AM	1.5	110	163	9.2	7.6	52	Yes	2738
11/18/23	6:00 AM	1.3	139	177	8.7	7.6	52	Yes	2183
11/19/23	6:00 AM	1.3	118	152	8.2	7.8	58	Yes	2545
11/20/23	6:00 AM	1.4	112	156	8.5	7.8	58	Yes	2723
11/21/23	6:00 AM	1.4	86	124	8.1	7.8	59	Yes	3619
11/22/23	6:00 AM	1.4	93	129	8.2	7.6	54	Yes	3388
11/23/23	6:00 AM	1.4	87	119	8.5	7.6	53	Yes	3257
11/24/23	6:00 AM	1.5	98	145	7.8	7.6	56	Yes	3283
11/25/23	6:00 AM	1.3	100	131	6.8	7.6	59	Yes	3156
11/26/23	6:00 AM	1.3	116	154	6.2	7.7	63	Yes	2657
11/27/23	6:00 AM	1.4	125	171	6.1	7.7	64	Yes	2461
11/28/23	6:00 AM	1.3	125	163	5.8	7.6	62	Yes	2460
11/29/23	6:00 AM	1.4	125	172	5.2	7.8	70	Yes	2438
11/30/23	6:00 AM	1.3	114	149	5.3	7.6	64	Yes	2625

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day