


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: December 2023								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
2	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
15	N/A	N/A	0.34	N/A	N/A	N/A	0.34	
16	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
17	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
18	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
19	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
20	N/A	N/A	0.21	N/A	N/A	N/A	0.21	
21	N/A	N/A	0.16	N/A	N/A	N/A	0.16	
22	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
23	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
24	N/A	N/A	0.19	N/A	N/A	N/A	0.19	
25	N/A	N/A	0.20	N/A	N/A	N/A	0.20	
26	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
27	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
28	N/A	N/A	0.27	N/A	N/A	N/A	0.27	
29	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
30	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
31	N/A	N/A	0.14	N/A	N/A	N/A	0.14	
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>				
95% of daily turbidity readings $\leq$ 1 NTU? <b>YES</b> All daily readings $\leq$ 5 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point $\geq$ 0.2 mg/l? <b>YES</b>		
Notes:				<b>PRINTED NAME: Joe Rogers</b>				
				SIGNATURE 			DATE 1/1/2024	
				PHONE #: (503) -723-3505			CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: December 2023**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
12/01/23	6:00 AM	1.5	98	149	5.1	7.6	66	Yes	3280
12/02/23	6:00 AM	1.4	92	126	6.4	7.6	60	Yes	3330
12/03/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/04/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/05/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/06/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/07/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/08/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/09/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/10/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/11/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/12/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/13/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/14/23	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/15/23	6:00 AM	1.5	114	169	7.9	8.1	68	Yes	2668
12/16/23	6:00 AM	1.5	102	150	7.8	7.9	63	Yes	2703
12/17/23	6:00 AM	1.6	98	155	7.8	8.1	69	Yes	3201
12/18/23	6:00 AM	1.5	91	137	5.9	7.9	71	Yes	3482
12/19/23	6:00 AM	1.5	94	140	6.5	8.2	77	Yes	3471
12/20/23	6:00 AM	1.6	94	147	6.9	7.9	68	Yes	3450
12/21/23	6:00 AM	1.5	95	141	6.8	7.9	67	Yes	3430
12/22/23	6:00 AM	1.5	95	143	6.5	7.9	69	Yes	3440
12/23/23	6:00 AM	1.6	99	158	6.5	7.9	69	Yes	3267
12/24/23	6:00 AM	1.4	96	137	6.2	8.1	74	Yes	3348
12/25/23	6:00 AM	1.4	87	123	6.4	8.0	71	Yes	3880
12/26/23	6:00 AM	1.4	69	95	6.5	7.9	67	Yes	4401
12/27/23	6:00 AM	1.4	92	130	7.1	8.0	68	Yes	3562
12/28/23	6:00 AM	1.4	98	139	7.1	7.9	65	Yes	3291
12/29/23	6:00 AM	1.4	93	133	7.1	7.9	65	Yes	3459
12/30/23	6:00 AM	1.4	84	120	7.1	7.9	65	Yes	3710
12/31/23	6:00AM	1.3	109	142	7.5	8.0	66	Yes	2822

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day