


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: January 2024							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.13	N/A	N/A	N/A	0.13
2	N/A	N/A	0.17	N/A	N/A	N/A	0.17
3	N/A	N/A	0.22	N/A	N/A	N/A	0.22
4	N/A	N/A	0.18	N/A	N/A	N/A	0.18
5	N/A	N/A	0.18	N/A	N/A	N/A	0.18
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
8	N/A	N/A	0.12	N/A	N/A	N/A	0.12
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
11	N/A	N/A	0.13	N/A	N/A	N/A	0.13
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
13	N/A	N/A	0.18	N/A	N/A	N/A	0.18
14	N/A	N/A	0.52	N/A	N/A	N/A	0.52
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	0.48	N/A	N/A	N/A	0.48
18	N/A	N/A	0.57	N/A	N/A	N/A	0.57
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
20	N/A	N/A	0.32	N/A	N/A	N/A	0.32
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
31	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		DATE 2/1/2024	
				PHONE #: (503) -723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: January 2024

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
01/01/24	6:00 AM	1.3	91	119	7.2	7.9	64	Yes	3467
01/02/24	6:00 AM	1.5	87	127	7.1	8.2	74	Yes	3891
01/03/24	6:00 AM	1.5	85	124	6.9	7.9	66	Yes	3939
01/04/24	6:00 AM	1.4	85	122	7.5	7.9	64	Yes	3960
01/05/24	6:00 AM	1.6	85	134	7.4	7.8	63	Yes	3915
01/06/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/07/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/08/24	6:00 AM	1.6	151	242	7.5	7.6	58	Yes	2007
01/09/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/10/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/11/24	6:00 AM	1.1	209	232	7.3	7.9	63	Yes	1383
01/12/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/13/24	6:00 AM	1.0	288	296	6.2	8.0	68	Yes	1057
01/14/24	6:00 AM	1.3	144	181	2.7	8.2	98	Yes	2143
01/15/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/16/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/17/24	6:00 AM	1.2	176	213	2.3	8.1	96	Yes	1769
01/18/24	6:00 AM	1.5	124	182	2.4	8.0	95	Yes	2472
01/19/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/20/24	6:00 AM	1.5	167	245	2.6	7.6	80	Yes	1737
01/21/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/22/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/23/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/24/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/25/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/26/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/27/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/28/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/29/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/30/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/31/24	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day