


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: February 2024								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
2	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
3	N/A	N/A	0.46	N/A	N/A	N/A	0.46	
4	N/A	N/A	0.43	N/A	N/A	N/A	0.43	
5	N/A	N/A	0.41	N/A	N/A	N/A	0.41	
6	N/A	N/A	0.42	N/A	N/A	N/A	0.42	
7	N/A	N/A	0.39	N/A	N/A	N/A	0.39	
8	N/A	N/A	0.37	N/A	N/A	N/A	0.37	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
12	N/A	N/A	0.34	N/A	N/A	N/A	0.34	
13	N/A	N/A	0.36	N/A	N/A	N/A	0.36	
14	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
17	N/A	N/A	0.38	N/A	N/A	N/A	0.38	
18	N/A	N/A	0.36	N/A	N/A	N/A	0.36	
19	N/A	N/A	0.35	N/A	N/A	N/A	0.35	
20	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
21	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
22	N/A	N/A	0.25	N/A	N/A	N/A	0.25	
23	N/A	N/A	0.29	N/A	N/A	N/A	0.29	
24	N/A	N/A	0.15	N/A	N/A	N/A	0.15	
25	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
28	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back)		All CL2 residual at entry point ≥ 0.2 mg/l?		
All daily readings ≤ 5 NTU? YES				YES		YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 3/1/2024	
				PHONE #: (503)-723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: February 2024

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
02/01/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/02/24	6:00 AM	1.6	100	159	7.8	7.8	62	Yes	3143
02/03/24	6:00 AM	1.2	95	112	8.0	7.7	57	Yes	3388
02/04/24	6:00 AM	1.1	86	90	6.8	7.7	59	Yes	3362
02/05/24	6:00 AM	1.5	91	137	6.8	7.7	62	Yes	3637
02/06/24	6:00 AM	1.5	88	130	6.8	7.9	67	Yes	3577
02/07/24	6:00 AM	1.4	78	108	7.4	7.8	62	Yes	4015
02/08/24	6:00 AM	1.3	105	132	7.0	8.1	70	Yes	2986
02/09/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/10/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/11/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/12/24	6:00 AM	1.1	291	306	7.2	8.1	67	Yes	1032
02/13/24	6:00 AM	1.1	187	196	7.4	8.3	72	Yes	1607
02/14/24	6:00 AM	1.3	172	217	6.0	7.9	68	Yes	1808
02/15/24	6:00 AM	DOWN	DOWN	DOWN	6.0	7.9	DOWN	DOWN	0
02/16/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/17/24	6:00 AM	1.2	159	193	5.1	8.1	77	Yes	1932
02/18/24	6:00 AM	1.2	155	186	4.8	8.2	82	Yes	1964
02/19/24	6:00 AM	1.2	158	187	5.6	8.2	78	Yes	1965
02/20/24	6:00 AM	1.2	153	181	6.0	8.2	76	Yes	1983
02/21/24	6:00 AM	1.2	155	185	6.1	8.2	76	Yes	1981
02/22/24	6:00 AM	1.1	205	217	6.6	8.2	72	Yes	1448
02/23/24	6:00 AM	1.2	168	207	7.0	7.9	65	Yes	1785
02/24/24	6:00 AM	1.2	175	212	6.7	7.9	66	Yes	1759
02/25/24	6:00 AM	1.2	166	200	6.9	7.7	60	Yes	1806
02/26/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/27/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/28/24	6:00 AM	1.1	212	238	7.2	7.6	56	Yes	1397
02/29/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day