


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: March 2024								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
5	N/A	N/A	0.42	N/A	N/A	N/A	0.42	
6	N/A	N/A	0.43	N/A	N/A	N/A	0.43	
7	N/A	N/A	0.41	N/A	N/A	N/A	0.41	
8	N/A	N/A	0.40	N/A	N/A	N/A	0.40	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	0.22	N/A	N/A	N/A	0.22	
11	N/A	N/A	0.23	N/A	N/A	N/A	0.23	
12	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
13	N/A	N/A	0.22	N/A	N/A	N/A	0.22	
14	N/A	N/A	0.27	N/A	N/A	N/A	0.27	
15	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
16	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
17	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
18	N/A	N/A	0.19	N/A	N/A	N/A	0.19	
19	N/A	N/A	0.21	N/A	N/A	N/A	0.21	
20	N/A	N/A	0.20	N/A	N/A	N/A	0.20	
21	N/A	N/A	0.22	N/A	N/A	N/A	0.22	
22	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
23	N/A	N/A	0.17	N/A	N/A	N/A	0.17	
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
26	N/A	N/A	0.46	N/A	N/A	N/A	0.46	
27	N/A	N/A	0.41	N/A	N/A	N/A	0.41	
28	N/A	N/A	0.40	N/A	N/A	N/A	0.40	
29	N/A	N/A	0.30	N/A	N/A	N/A	0.30	
30	N/A	N/A	0.31	N/A	N/A	N/A	0.31	
31	N/A	N/A	0.26	N/A	N/A	N/A	0.26	
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>				
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b> All daily readings ≤ 5 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>		
<b>Notes:</b>				<b>PRINTED NAME: Joe Rogers</b>				
				SIGNATURE 			DATE 4/1/2024	
				PHONE #: (503) 723-3505			CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: March 2024**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
03/01/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/02/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/03/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/04/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/05/24	6:00 AM	1.3	216	283	7.1	8.0	67	Yes	1406
03/06/24	6:00 AM	1.2	162	201	5.8	8.1	74	Yes	1763
03/07/24	6:00 AM	1.2	160	189	6.0	8.0	70	Yes	1852
03/08/24	6:00 AM	1.2	335	402	6.1	7.9	68	Yes	896
03/09/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/10/24	6:00 AM	1.8	163	298	6.2	7.8	70	Yes	1800
03/11/24	6:00 AM	1.4	155	214	6.7	8.0	69	Yes	1963
03/12/24	6:00 AM	1.3	172	220	6.5	8.1	72	Yes	1766
03/13/24	6:00 AM	1.2	193	239	6.9	8.1	70	Yes	1557
03/14/24	6:00 AM	1.2	212	261	6.0	8.2	77	Yes	1380
03/15/24	6:00 AM	1.3	293	384	7.0	8.2	73	Yes	988
03/16/24	6:00 AM	1.2	295	339	7.5	8.2	70	Yes	983
03/17/24	6:00 AM	1.3	255	332	7.9	8.2	69	Yes	1149
03/18/24	6:00 AM	1.3	247	318	8.4	8.1	65	Yes	1204
03/19/24	6:00 AM	1.3	246	307	8.6	8.2	66	Yes	1208
03/20/24	6:00 AM	1.3	242	305	9.0	8.0	60	Yes	1212
03/21/24	6:00 AM	1.8	243	427	8.9	8.0	64	Yes	1193
03/22/24	6:00 AM	1.1	263	286	9.1	7.9	56	Yes	1116
03/23/24	6:00 AM	1.1	259	272	8.5	8.3	67	Yes	1145
03/24/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/25/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/26/24	6:00 AM	1.1	254	280	8.5	8.2	65	Yes	1210
03/27/24	6:00 AM	1.3	235	296	8.4	8.2	67	Yes	1249
03/28/24	6:00 AM	1.3	223	292	7.8	7.9	62	Yes	1316
03/29/24	6:00 AM	1.4	162	228	7.4	7.8	62	Yes	1834
03/30/24	6:00 AM	1.4	152	214	7.8	7.7	58	Yes	1932
03/31/24	6:00AM	1.4	153	208	7.9	7.7	57	Yes	1915

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met. notify DWP by end of next business day