


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: April 2024							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.19	N/A	N/A	N/A	0.19
2	N/A	N/A	0.17	N/A	N/A	N/A	0.17
3	N/A	N/A	0.16	N/A	N/A	N/A	0.16
4	N/A	N/A	0.15	N/A	N/A	N/A	0.15
5	N/A	N/A	0.11	N/A	N/A	N/A	0.11
6	N/A	N/A	0.11	N/A	N/A	N/A	0.11
7	N/A	N/A	0.11	N/A	N/A	N/A	0.11
8	N/A	N/A	0.11	N/A	N/A	N/A	0.11
9	N/A	N/A	0.19	N/A	N/A	N/A	0.19
10	N/A	N/A	0.15	N/A	N/A	N/A	0.15
11	N/A	N/A	0.10	N/A	N/A	N/A	0.10
12	N/A	N/A	0.10	N/A	N/A	N/A	0.10
13	N/A	N/A	0.12	N/A	N/A	N/A	0.12
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.11	N/A	N/A	N/A	0.11
16	N/A	N/A	0.43	N/A	N/A	N/A	0.43
17	N/A	N/A	0.37	N/A	N/A	N/A	0.37
18	N/A	N/A	0.47	N/A	N/A	N/A	0.47
19	N/A	N/A	0.30	N/A	N/A	N/A	0.30
20	N/A	N/A	0.30	N/A	N/A	N/A	0.30
21	N/A	N/A	0.24	N/A	N/A	N/A	0.24
22	N/A	N/A	0.32	N/A	N/A	N/A	0.32
23	N/A	N/A	0.31	N/A	N/A	N/A	0.31
24	N/A	N/A	0.44	N/A	N/A	N/A	0.44
25	N/A	N/A	0.40	N/A	N/A	N/A	0.40
26	N/A	N/A	0.25	N/A	N/A	N/A	0.25
27	N/A	N/A	0.25	N/A	N/A	N/A	0.25
28	N/A	N/A	0.20	N/A	N/A	N/A	0.20
29	N/A	N/A	0.26	N/A	N/A	N/A	0.26
30	N/A	N/A	0.25	N/A	N/A	N/A	0.25
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back)		All CL2 residual at entry point ≥ 0.2 mg/l?	
All daily readings ≤ 5 NTU? YES				YES		YES	
Notes:				PRINTED NAME: Joe Rogers			
				SIGNATURE 		DATE 5/1/2024	
				PHONE #: (503) -723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:-: WTP-B1 Month/Year: April 2024

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
04/01/24	6:00 AM	1.3	164	211	8.6	8.2	66	Yes	1899
04/02/24	6:00 AM	1.3	161	211	9.1	8.2	64	Yes	1891
04/03/24	6:00 AM	1.3	155	208	9.9	7.6	48	Yes	1892
04/04/24	6:00 AM	1.2	156	189	9.2	7.9	57	Yes	1898
04/05/24	6:00 AM	1.3	141	189	8.1	7.8	59	Yes	2076
04/06/24	6:00 AM	1.3	156	203	9.1	7.7	53	Yes	1905
04/07/24	6:00 AM	1.3	156	203	7.7	7.8	60	Yes	1898
04/08/24	6:00 AM	1.4	161	218	8.5	7.8	57	Yes	1841
04/09/24	6:00 AM	1.3	130	164	8.6	7.7	55	Yes	2257
04/10/24	6:00 AM	1.5	159	232	9.1	7.8	56	Yes	1888
04/11/24	6:00 AM	1.2	159	191	9.5	7.7	52	Yes	1846
04/12/24	6:00 AM	1.1	180	202	9.8	7.7	50	Yes	1706
04/13/24	6:00 AM	1.1	194	211	10.2	7.7	48	Yes	1514
04/14/24	6:00 AM	1.3	318	397	9.8	8.0	57	Yes	911
04/15/24	6:00 AM	1.6	120	197	9.2	8.2	67	Yes	2530
04/16/24	6:00 AM	1.2	136	164	9.3	7.9	56	Yes	2185
04/17/24	6:00 AM	1.5	70	106	9.5	7.8	55	Yes	4289
04/18/24	6:00 AM	1.2	115	143	10.1	7.7	50	Yes	2740
04/19/24	6:00 AM	1.2	109	132	10.3	7.7	49	Yes	2800
04/20/24	6:00 AM	1.4	83	117	10.8	7.7	48	Yes	3712
04/21/24	6:00 AM	1.5	61	92	9.8	7.7	52	Yes	5419
04/22/24	6:00 AM	1.6	64	102	10.6	7.7	50	Yes	5459
04/23/24	6:00 AM	1.3	65	85	11.2	7.6	44	Yes	5420
04/24/24	6:00 AM	1.3	67	90	11.8	7.6	42	Yes	5352
04/25/24	6:00 AM	1.4	65	89	11.6	7.6	43	Yes	5436
04/26/24	6:00 AM	1.3	67	90	10.5	7.6	46	Yes	5008
04/27/24	6:00 AM	1.3	80	103	11.0	7.6	45	Yes	4229
04/28/24	6:00 AM	1.2	103	126	10.0	7.8	52	Yes	3171
04/29/24	6:00 AM	1.2	108	128	10.2	7.8	51	Yes	2904
04/30/24	6:00 AM	1.3	100	130	9.6	7.7	51	Yes	3101

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day