


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: June 2024							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.18	N/A	N/A	N/A	0.18
2	N/A	N/A	0.15	N/A	N/A	N/A	0.15
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	0.45	N/A	N/A	N/A	0.45
5	N/A	N/A	0.22	N/A	N/A	N/A	0.22
6	N/A	N/A	0.30	N/A	N/A	N/A	0.30
7	N/A	N/A	0.27	N/A	N/A	N/A	0.27
8	N/A	N/A	0.25	N/A	N/A	N/A	0.25
9	N/A	N/A	0.21	N/A	N/A	N/A	0.21
10	N/A	N/A	0.20	N/A	N/A	N/A	0.20
11	N/A	N/A	0.25	N/A	N/A	N/A	0.25
12	N/A	N/A	0.20	N/A	N/A	N/A	0.20
13	N/A	N/A	0.24	N/A	N/A	N/A	0.24
14	N/A	N/A	0.16	N/A	N/A	N/A	0.16
15	N/A	N/A	0.16	N/A	N/A	N/A	0.16
16	N/A	N/A	0.14	N/A	N/A	N/A	0.14
17	N/A	N/A	0.14	N/A	N/A	N/A	0.14
18	N/A	N/A	0.13	N/A	N/A	N/A	0.13
19	N/A	N/A	0.14	N/A	N/A	N/A	0.14
20	N/A	N/A	0.15	N/A	N/A	N/A	0.15
21	N/A	N/A	0.14	N/A	N/A	N/A	0.14
22	N/A	N/A	0.14	N/A	N/A	N/A	0.14
23	N/A	N/A	0.15	N/A	N/A	N/A	0.15
24	N/A	N/A	0.19	N/A	N/A	N/A	0.19
25	N/A	N/A	0.28	N/A	N/A	N/A	0.28
26	N/A	N/A	0.20	N/A	N/A	N/A	0.20
27	N/A	N/A	0.16	N/A	N/A	N/A	0.16
28	N/A	N/A	0.14	N/A	N/A	N/A	0.14
29	N/A	N/A	0.15	N/A	N/A	N/A	0.15
30	N/A	N/A	0.14	N/A	N/A	N/A	0.14
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES				PRINTED NAME: Joe Rogers SIGNATURE  DATE 7/1/2024 PHONE #: (503) 723-3505 CERT #: T-09162			
Notes:							

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: June 2024

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
06/01/24	6:00 AM	1.5	72	104	14.6	7.6	34	Yes	4550
06/02/24	6:00 AM	1.3	79	103	14.0	7.8	39	Yes	4195
06/03/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/04/24	6:00 AM	1.1	98	108	13.0	7.7	39	Yes	3105
06/05/24	6:00 AM	1.3	75	100	11.3	7.9	49	Yes	4077
06/06/24	6:00 AM	1.3	70	93	13.5	7.7	39	Yes	4741
06/07/24	6:00 AM	1.4	71	96	14.6	7.7	35	Yes	4827
06/08/24	6:00 AM	1.2	72	90	14.9	7.7	34	Yes	4805
06/09/24	6:00 AM	1.3	72	90	14.7	7.6	33	Yes	4831
06/10/24	6:00 AM	1.2	72	85	16.1	7.7	31	Yes	4847
06/11/24	6:00 AM	1.2	70	84	16.7	7.6	29	Yes	4989
06/12/24	6:00 AM	1.2	73	86	16.1	7.7	31	Yes	4791
06/13/24	6:00 AM	1.2	72	86	16.5	7.7	31	Yes	4842
06/14/24	6:00 AM	1.2	71	89	16.1	7.6	30	Yes	4914
06/15/24	6:00 AM	1.2	70	87	16.4	7.6	30	Yes	4959
06/16/24	6:00 AM	1.2	72	87	15.1	7.6	32	Yes	4857
06/17/24	6:00 AM	1.3	73	93	14.6	7.7	35	Yes	4774
06/18/24	6:00 AM	1.2	61	73	13.9	7.6	35	Yes	4866
06/19/24	6:00 AM	1.1	75	82	15.9	7.6	30	Yes	4793
06/20/24	6:00 AM	1.1	63	71	16.8	7.6	29	Yes	5938
06/21/24	6:00 AM	1.2	67	81	17.6	7.6	28	Yes	5486
06/22/24	6:00 AM	1.2	66	78	18.2	7.6	27	Yes	5563
06/23/24	6:00 AM	1.1	68	75	18.1	7.6	27	Yes	5402
06/24/24	6:00 AM	1.2	83	96	17.1	7.7	30	Yes	3944
06/25/24	6:00 AM	1.2	77	91	18.3	7.6	27	Yes	4119
06/26/24	6:00 AM	1.2	61	72	19.1	7.6	26	Yes	5716
06/27/24	6:00 AM	1.2	71	88	17.2	7.6	29	Yes	4990
06/28/24	6:00 AM	1.3	74	96	17.5	7.6	29	Yes	4865
06/29/24	6:00 AM	1.2	73	88	18.9	7.6	26	Yes	4886
06/30/24	6:00 AM	1.2	90	106	18.7	7.9	29	Yes	3563

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day