


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

**System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: September 2024**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.10	N/A	N/A	N/A	0.10
2	N/A	N/A	0.10	N/A	N/A	N/A	0.10
3	N/A	N/A	0.11	N/A	N/A	N/A	0.11
4	N/A	N/A	0.11	N/A	N/A	N/A	0.11
5	N/A	N/A	0.12	N/A	N/A	N/A	0.12
6	N/A	N/A	0.13	N/A	N/A	N/A	0.13
7	N/A	N/A	0.13	N/A	N/A	N/A	0.13
8	N/A	N/A	0.12	N/A	N/A	N/A	0.12
9	N/A	N/A	0.12	N/A	N/A	N/A	0.12
10	N/A	N/A	0.10	N/A	N/A	N/A	0.10
11	N/A	N/A	0.11	N/A	N/A	N/A	0.11
12	N/A	N/A	0.11	N/A	N/A	N/A	0.11
13	N/A	N/A	0.10	N/A	N/A	N/A	0.10
14	N/A	N/A	0.10	N/A	N/A	N/A	0.10
15	N/A	N/A	0.10	N/A	N/A	N/A	0.10
16	N/A	N/A	0.10	N/A	N/A	N/A	0.10
17	N/A	N/A	0.10	N/A	N/A	N/A	0.10
18	N/A	N/A	0.11	N/A	N/A	N/A	0.11
19	N/A	N/A	0.11	N/A	N/A	N/A	0.11
20	N/A	N/A	0.11	N/A	N/A	N/A	0.11
21	N/A	N/A	0.11	N/A	N/A	N/A	0.11
22	N/A	N/A	0.11	N/A	N/A	N/A	0.11
23	N/A	N/A	0.10	N/A	N/A	N/A	0.10
24	N/A	N/A	0.11	N/A	N/A	N/A	0.11
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10
26	N/A	N/A	0.10	N/A	N/A	N/A	0.10
27	N/A	N/A	0.11	N/A	N/A	N/A	0.11
28	N/A	N/A	0.12	N/A	N/A	N/A	0.12
29	N/A	N/A	0.11	N/A	N/A	N/A	0.11
30	N/A	N/A	0.11	N/A	N/A	N/A	0.11

<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>	<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b> All daily readings ≤ 5 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
<b>Notes:</b>	<b>PRINTED NAME: Joe Rogers</b>	
	<b>SIGNATURE</b> 	<b>DATE 10/1/2024</b>
	<b>PHONE #: (503)-723-3505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: September 2024**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
09/01/24	6:00 AM	1.2	62	76	19.4	7.7	27	Yes	5185
09/02/24	6:00 AM	1.2	60	74	19.1	7.7	27	Yes	5565
09/03/24	6:00 AM	1.2	60	71	17.5	7.6	28	Yes	4649
09/04/24	6:00 AM	1.0	63	64	18.2	7.6	26	Yes	4416
09/05/24	6:00 AM	1.1	59	67	19.1	7.7	27	Yes	4736
09/06/24	6:00 AM	1.2	54	65	19.3	7.6	26	Yes	5992
09/07/24	6:00 AM	1.2	45	54	19.3	7.7	27	Yes	6398
09/08/24	6:00 AM	1.3	56	70	19.2	7.8	28	Yes	6479
09/09/24	6:00 AM	1.3	49	65	19.2	7.7	27	Yes	6461
09/10/24	6:00 AM	1.1	75	86	19.0	8.0	30	Yes	3751
09/11/24	6:00 AM	1.1	57	62	18.5	7.6	26	Yes	5247
09/12/24	6:00 AM	1.2	73	86	17.7	7.8	30	Yes	3953
09/13/24	6:00 AM	1.3	73	94	17.2	7.8	31	Yes	3898
09/14/24	6:00 AM	1.2	53	63	17.6	7.8	30	Yes	4878
09/15/24	6:00 AM	1.2	74	91	17.7	7.9	31	Yes	3975
09/16/24	6:00 AM	1.2	53	61	17.0	7.8	31	Yes	5584
09/17/24	6:00 AM	1.2	59	70	16.7	7.7	31	Yes	5375
09/18/24	6:00 AM	1.2	59	70	15.7	7.8	34	Yes	5237
09/19/24	6:00 AM	1.2	58	68	16.4	7.8	32	Yes	5770
09/20/24	6:00 AM	1.2	55	64	16.2	7.7	31	Yes	6107
09/21/24	6:00 AM	1.2	56	65	16.1	7.8	33	Yes	5887
09/22/24	6:00 AM	1.1	58	66	16.0	7.7	31	Yes	5446
09/23/24	6:00 AM	1.0	60	63	15.9	7.8	32	Yes	5348
09/24/24	6:00 AM	1.0	54	54	16.9	7.7	29	Yes	5348
09/25/24	6:00 AM	1.1	63	71	17.5	7.7	29	Yes	4338
09/26/24	6:00 AM	1.2	58	72	15.5	7.6	31	Yes	5233
09/27/24	6:00 AM	1.3	60	78	16.3	7.6	30	Yes	5348
09/28/24	6:00 AM	1.2	59	73	15.8	7.7	32	Yes	5431
09/29/24	6:00 AM	1.2	72	85	15.7	7.8	34	Yes	3898
09/30/24	6:00 AM	1.1	59	67	14.8	7.6	32	Yes	5390

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day