

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: October 2024							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.06	N/A	N/A	N/A	0.06
2	N/A	N/A	0.05	N/A	N/A	N/A	0.05
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06
5	N/A	N/A	0.05	N/A	N/A	N/A	0.05
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.08	N/A	N/A	N/A	0.08
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.06	N/A	N/A	N/A	0.06
12	N/A	N/A	0.05	N/A	N/A	N/A	0.05
13	N/A	N/A	0.08	N/A	N/A	N/A	0.08
14	N/A	N/A	0.07	N/A	N/A	N/A	0.07
15	N/A	N/A	0.07	N/A	N/A	N/A	0.07
16	N/A	N/A	0.07	N/A	N/A	N/A	0.07
17	N/A	N/A	0.07	N/A	N/A	N/A	0.07
18	N/A	N/A	0.09	N/A	N/A	N/A	0.09
19	N/A	N/A	0.10	N/A	N/A	N/A	0.10
20	N/A	N/A	0.10	N/A	N/A	N/A	0.10
21	N/A	N/A	0.10	N/A	N/A	N/A	0.10
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.09	N/A	N/A	N/A	0.09
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09
25	N/A	N/A	0.07	N/A	N/A	N/A	0.07
26	N/A	N/A	0.07	N/A	N/A	N/A	0.07
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
28	N/A	N/A	0.11	N/A	N/A	N/A	0.11
29	N/A	N/A	0.12	N/A	N/A	N/A	0.12
30	N/A	N/A	0.10	N/A	N/A	N/A	0.10
31	N/A	N/A	0.10	N/A	N/A	N/A	0.10
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES							
Notes:				PRINTED NAME: <i>Bret Bienerth</i>			
				SIGNATURE <i>Bret Bienerth</i>			DATE 11/1/2024
				PHONE #: (503) -723-3505			CERT #: T-09162

T-08749

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: October 2024

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
10/01/24	6:00 AM	1.3	54	68	14.3	7.6	34	Yes	6471
10/02/24	6:00 AM	1.3	55	69	14.8	7.7	34	Yes	6104
10/03/24	6:00 AM	1.2	54	65	14.3	7.8	37	Yes	5843
10/04/24	6:00 AM	1.1	61	69	14.0	7.8	38	Yes	4836
10/05/24	6:00 AM	1.3	60	75	13.1	7.9	43	Yes	5347
10/06/24	6:00 AM	1.1	80	88	12.7	7.9	44	Yes	3588
10/07/24	6:00 AM	1.1	59	67	13.8	7.8	38	Yes	5296
10/08/24	6:00 AM	1.2	55	64	14.1	7.6	34	Yes	5811
10/09/24	6:00 AM	1.1	57	63	13.9	7.6	35	Yes	5109
10/10/24	6:00 AM	1.1	61	69	13.3	7.7	38	Yes	5257
10/11/24	6:00 AM	1.1	61	67	12.8	7.7	40	Yes	5262
10/12/24	6:00 AM	1.1	61	67	12.5	7.7	41	Yes	5304
10/13/24	6:00 AM	1.2	62	71	13.2	7.6	37	Yes	5228
10/14/24	6:00 AM	1.1	60	68	13.2	7.5	36	Yes	5319
10/15/24	6:00 AM	1.1	57	64	13.6	7.6	36	Yes	5123
10/16/24	6:00 AM	1.5	75	111	13.6	7.6	38	Yes	3875
10/17/24	6:00 AM	1.1	77	88	13.0	7.7	40	Yes	3627
10/18/24	6:00 AM	1.5	76	112	12.2	7.6	42	Yes	3571
10/19/24	6:00 AM	1.4	67	94	12.3	7.7	43	Yes	4220
10/20/24	6:00 AM	1.3	67	84	12.2	7.7	43	Yes	4620
10/21/24	6:00 AM	1.1	76	83	12.7	7.6	39	Yes	3723
10/22/24	6:00 AM	1.0	108	112	13.0	7.5	36	Yes	2423
10/23/24	6:00 AM	1.3	110	140	15.0	7.8	35	Yes	2398
10/24/24	6:00 AM	1.2	140	168	12.0	7.7	43	Yes	1883
10/25/24	6:00 AM	1.1	72	82	11.2	7.5	42	Yes	3854
10/26/24	6:00 AM	1.4	71	102	10.7	7.6	46	Yes	4198
10/27/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
10/28/24	6:00 AM	1.1	65	72	11.5	7.7	44	Yes	4002
10/29/24	6:00 AM	1.2	68	84	12.2	7.6	41	Yes	4052
10/30/24	6:00 AM	1.2	92	109	11.3	7.5	42	Yes	3026
10/31/24	6:00AM	1.3	88	110	10.7	7.5	44	Yes	3138

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day