

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: November 2024							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.10	N/A	N/A	N/A	0.10
5	N/A	N/A	0.11	N/A	N/A	N/A	0.11
6	N/A	N/A	0.11	N/A	N/A	N/A	0.11
7	N/A	N/A	0.14	N/A	N/A	N/A	0.14
8	N/A	N/A	0.09	N/A	N/A	N/A	0.09
9	N/A	N/A	0.14	N/A	N/A	N/A	0.14
10	N/A	N/A	0.16	N/A	N/A	N/A	0.16
11	N/A	N/A	0.12	N/A	N/A	N/A	0.12
12	N/A	N/A	0.15	N/A	N/A	N/A	0.15
13	N/A	N/A	0.12	N/A	N/A	N/A	0.12
14	N/A	N/A	0.14	N/A	N/A	N/A	0.14
15	N/A	N/A	0.16	N/A	N/A	N/A	0.16
16	N/A	N/A	0.14	N/A	N/A	N/A	0.14
17	N/A	N/A	0.19	N/A	N/A	N/A	0.19
18	N/A	N/A	0.24	N/A	N/A	N/A	0.24
19	N/A	N/A	0.26	N/A	N/A	N/A	0.26
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
21	N/A	N/A	0.47	N/A	N/A	N/A	0.47
22	N/A	N/A	0.45	N/A	N/A	N/A	0.45
23	N/A	N/A	0.51	N/A	N/A	N/A	0.51
24	N/A	N/A	0.39	N/A	N/A	N/A	0.39
25	N/A	N/A	0.36	N/A	N/A	N/A	0.36
26	N/A	N/A	0.34	N/A	N/A	N/A	0.34
27	N/A	N/A	0.29	N/A	N/A	N/A	0.29
28	N/A	N/A	0.23	N/A	N/A	N/A	0.23
29	N/A	N/A	0.19	N/A	N/A	N/A	0.19
30	N/A	N/A	0.17	N/A	N/A	N/A	0.17
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings $\leq$ 1 NTU? YES All daily readings $\leq$ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point $\geq$ 0.2 mg/l? YES	
Notes:				PRINTED NAME: <i>Bret Bienerth</i>			
				SIGNATURE <i>Bret Bienerth</i>		DATE 12/4/2024	
				PHONE #: (503) -723-3505		CERT #: T-08749	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: November 2024

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
11/01/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/02/24	6:00 AM	1.1	99	104	10.5	7.6	45	Yes	2702
11/03/24	6:00 AM	1.1	80	89	9.5	7.6	49	Yes	3473
11/04/24	6:00 AM	1.1	79	90	9.2	7.7	52	Yes	3536
11/05/24	6:00 AM	1.1	81	91	9.2	7.5	48	Yes	3498
11/06/24	6:00 AM	1.1	79	89	8.7	7.6	52	Yes	3525
11/07/24	6:00 AM	1.1	71	80	8.8	7.6	51	Yes	3746
11/08/24	6:00 AM	1.3	62	79	8.6	7.5	50	Yes	4589
11/09/24	6:00 AM	1.3	71	94	8.3	7.5	51	Yes	4179
11/10/24	6:00 AM	1.4	69	94	9.4	7.6	50	Yes	4335
11/11/24	6:00 AM	1.5	65	100	8.7	7.6	54	Yes	4457
11/12/24	6:00 AM	1.1	68	78	9.4	7.6	49	Yes	3757
11/13/24	6:00 AM	1.3	67	85	8.7	7.6	52	Yes	4238
11/14/24	6:00 AM	1.1	73	77	9.0	7.6	50	Yes	3894
11/15/24	6:00 AM	1.3	63	80	8.7	7.6	52	Yes	3877
11/16/24	6:00 AM	1.2	75	89	8.0	7.6	54	Yes	3846
11/17/24	6:00 AM	1.1	71	78	8.2	7.5	51	Yes	3851
11/18/24	6:00 AM	1.2	74	92	8.4	7.6	53	Yes	3473
11/19/24	6:00 AM	1.1	62	69	9.3	7.7	51	Yes	4382
11/20/24	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/21/24	6:00 AM	1.3	68	87	7.3	7.6	57	Yes	3971
11/22/24	6:00 AM	1.2	98	117	7.1	7.6	57	Yes	2721
11/23/24	6:00 AM	1.3	103	136	7.8	7.6	55	Yes	2637
11/24/24	6:00 AM	1.3	104	138	7.7	7.6	56	Yes	2570
11/25/24	6:00 AM	1.4	95	133	7.9	7.5	53	Yes	2700
11/26/24	6:00 AM	1.4	71	98	7.5	7.6	56	Yes	3887
11/27/24	6:00 AM	1.5	85	126	7.4	7.6	56	Yes	3251
11/28/24	6:00 AM	1.5	88	128	6.6	7.5	57	Yes	3167
11/29/24	6:00 AM	1.5	84	126	6.6	7.5	58	Yes	3260
11/30/24	6:00 AM	1.6	75	118	6.4	7.5	59	Yes	3812

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day