

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP: WTP-B1 Month/Year: January 2025							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.58	N/A	N/A	N/A	0.58
2	N/A	N/A	0.55	N/A	N/A	N/A	0.55
3	N/A	N/A	0.61	N/A	N/A	N/A	0.61
4	N/A	N/A	0.59	N/A	N/A	N/A	0.59
5	N/A	N/A	0.63	N/A	N/A	N/A	0.63
6	N/A	N/A	0.57	N/A	N/A	N/A	0.57
7	N/A	N/A	0.45	N/A	N/A	N/A	0.45
8	N/A	N/A	0.51	N/A	N/A	N/A	0.51
9	N/A	N/A	0.41	N/A	N/A	N/A	0.41
10	N/A	N/A	0.35	N/A	N/A	N/A	0.35
11	N/A	N/A	0.38	N/A	N/A	N/A	0.38
12	N/A	N/A	0.38	N/A	N/A	N/A	0.38
13	N/A	N/A	0.39	N/A	N/A	N/A	0.39
14	N/A	N/A	0.42	N/A	N/A	N/A	0.42
15	N/A	N/A	0.40	N/A	N/A	N/A	0.40
16	N/A	N/A	0.32	N/A	N/A	N/A	0.32
17	N/A	N/A	0.29	N/A	N/A	N/A	0.29
18	N/A	N/A	0.40	N/A	N/A	N/A	0.40
19	N/A	N/A	0.32	N/A	N/A	N/A	0.32
20	N/A	N/A	0.33	N/A	N/A	N/A	0.33
21	N/A	N/A	0.28	N/A	N/A	N/A	0.28
22	N/A	N/A	0.22	N/A	N/A	N/A	0.22
23	N/A	N/A	0.20	N/A	N/A	N/A	0.20
24	N/A	N/A	0.25	N/A	N/A	N/A	0.25
25	N/A	N/A	0.22	N/A	N/A	N/A	0.22
26	N/A	N/A	0.21	N/A	N/A	N/A	0.21
27	N/A	N/A	0.20	N/A	N/A	N/A	0.20
28	N/A	N/A	0.40	N/A	N/A	N/A	0.40
29	N/A	N/A	0.15	N/A	N/A	N/A	0.15
30	N/A	N/A	0.13	N/A	N/A	N/A	0.13
31	N/A	N/A	0.19	N/A	N/A	N/A	0.19
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings $\leq$ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point $\geq$ 0.2 mg/l? YES	
All daily readings $\leq$ 5 NTU? YES							
Notes:				PRINTED NAME: Bret Bienerth			
				SIGNATURE <i>Bret Bienerth</i>		DATE 2/1/2025	
				PHONE #: (503) -723-3505		CERT #: T-08749	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: January 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
01/01/25	6:00 AM	1.2	61	76	6.4	8.2	75	Yes	4505
01/02/25	6:00 AM	1.1	65	74	6.4	8.1	71	Yes	4053
01/03/25	6:00 AM	1.3	69	89	6.2	7.8	65	Yes	3935
01/04/25	6:00 AM	1.2	133	154	6.2	8.2	75	Yes	1935
01/05/25	6:00 AM	1.2	95	118	6.5	8.1	72	Yes	2888
01/06/25	6:00 AM	1.2	87	106	7.3	8.3	74	Yes	3128
01/07/25	6:00 AM	1.3	69	87	6.9	7.9	65	Yes	4096
01/08/25	6:00 AM	1.5	76	113	6.6	8.3	79	Yes	3591
01/09/25	6:00 AM	1.3	62	83	6.5	8.1	73	Yes	4334
01/10/25	6:00 AM	1.5	68	99	7.0	8.1	71	Yes	3860
01/11/25	6:00 AM	1.6	65	103	6.0	8.0	75	Yes	4366
01/12/25	6:00 AM	1.6	66	105	6.3	8.0	73	Yes	4418
01/13/25	6:00 AM	1.4	75	102	6.2	8.1	74	Yes	3753
01/14/25	6:00 AM	1.4	82	112	6.0	8.0	72	Yes	3432
01/15/25	6:00 AM	1.4	80	110	5.8	8.1	76	Yes	3529
01/16/25	6:00 AM	1.4	76	103	5.5	7.9	71	Yes	3419
01/17/25	6:00 AM	1.5	72	105	5.5	8.0	75	Yes	3815
01/18/25	6:00 AM	1.4	53	75	4.8	7.9	75	Yes	5382
01/19/25	6:00 AM	1.4	75	102	4.5	8.1	82	Yes	3744
01/20/25	6:00 AM	1.4	63	90	4.1	7.9	80	Yes	4966
01/21/25	6:00 AM	1.2	80	95	3.9	7.7	73	Yes	3389
01/22/25	6:00 AM	1.2	81	97	4.2	7.9	77	Yes	3326
01/23/25	6:00 AM	1.4	77	104	3.4	8.1	90	Yes	3677
01/24/25	6:00 AM	1.6	64	99	3.5	7.8	82	Yes	4947
01/25/25	6:00 AM	1.5	82	119	4.0	8.0	84	Yes	4219
01/26/25	6:00 AM	1.5	80	120	3.8	7.7	76	Yes	4209
01/27/25	6:00 AM	1.2	95	117	2.9	7.9	85	Yes	3375
01/28/25	6:00 AM	1.2	143	169	3.1	8.2	94	Yes	2325
01/29/25	6:00 AM	1.6	102	165	3.1	8.0	92	Yes	3620
01/30/25	6:00 AM	1.6	112	175	2.8	8.0	93	Yes	3258
01/31/25	6:00AM	1.6	105	165	3.1	8.1	95	Yes	3379

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day