

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP: WTP-B1 Month/Year: March 2025							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.61	N/A	N/A	N/A	0.61
2	N/A	N/A	0.42	N/A	N/A	N/A	0.42
3	N/A	N/A	0.39	N/A	N/A	N/A	0.39
4	N/A	N/A	0.33	N/A	N/A	N/A	0.33
5	N/A	N/A	0.28	N/A	N/A	N/A	0.28
6	N/A	N/A	0.27	N/A	N/A	N/A	0.27
7	N/A	N/A	0.51	N/A	N/A	N/A	0.51
8	N/A	N/A	0.24	N/A	N/A	N/A	0.24
9	N/A	N/A	0.20	N/A	N/A	N/A	0.20
10	N/A	N/A	0.20	N/A	N/A	N/A	0.20
11	N/A	N/A	0.19	N/A	N/A	N/A	0.19
12	N/A	N/A	0.20	N/A	N/A	N/A	0.20
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
14	N/A	N/A	0.28	N/A	N/A	N/A	0.28
15	N/A	N/A	0.27	N/A	N/A	N/A	0.27
16	N/A	N/A	0.28	N/A	N/A	N/A	0.28
17	N/A	N/A	0.29	N/A	N/A	N/A	0.29
18	N/A	N/A	0.36	N/A	N/A	N/A	0.36
19	N/A	N/A	0.47	N/A	N/A	N/A	0.47
20	N/A	N/A	0.42	N/A	N/A	N/A	0.42
21	N/A	N/A	0.44	N/A	N/A	N/A	0.44
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
24	N/A	N/A	0.39	N/A	N/A	N/A	0.39
25	N/A	N/A	0.69	N/A	N/A	N/A	0.69
26	N/A	N/A	0.69	N/A	N/A	N/A	0.69
27	N/A	N/A	0.55	N/A	N/A	N/A	0.55
28	N/A	N/A	0.41	N/A	N/A	N/A	0.41
29	N/A	N/A	0.55	N/A	N/A	N/A	0.55
30	N/A	N/A	0.44	N/A	N/A	N/A	0.44
31	N/A	N/A	0.33	N/A	N/A	N/A	0.33
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings $\leq$ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point $\geq$ 0.2 mg/l? YES	
All daily readings $\leq$ 5 NTU? YES							
Notes:				PRINTED NAME: Steve Prestwood			
				SIGNATURE <i>Steve Prestwood</i>		DATE 4/1/2025	
				PHONE #: (503) -723-3505		CERT #: T-8060FE	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: March 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
03/01/25	6:00 AM	1.0	185	185	7.2	8.2	69	Yes	2000
03/02/25	6:00 AM	1.1	168	183	7.7	8.1	66	Yes	2025
03/03/25	6:00 AM	1.1	170	182	8.0	8.1	64	Yes	1962
03/04/25	6:00 AM	1.1	140	157	7.6	8.1	66	Yes	2224
03/05/25	6:00 AM	1.1	149	167	7.7	8.2	69	Yes	2230
03/06/25	6:00 AM	1.1	154	169	7.8	7.5	52	Yes	2190
03/07/25	6:00 AM	1.0	138	141	7.5	7.5	52	Yes	2801
03/08/25	6:00 AM	1.4	112	153	6.9	7.5	56	Yes	3105
03/09/25	6:00 AM	1.3	122	161	7.9	8.0	64	Yes	2828
03/10/25	6:00 AM	1.3	111	139	8.0	8.0	63	Yes	3023
03/11/25	6:00 AM	1.1	125	139	7.7	8.0	63	Yes	2777
03/12/25	6:00 AM	1.2	122	151	8.6	8.4	71	Yes	2788
03/13/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/14/25	6:00 AM	1.2	175	202	7.7	7.8	59	Yes	1920
03/15/25	6:00 AM	1.2	173	205	7.0	8.3	75	Yes	1909
03/16/25	6:00 AM	1.0	249	249	7.1	8.4	75	Yes	1306
03/17/25	6:00 AM	1.3	192	253	6.9	7.6	58	Yes	1774
03/18/25	6:00 AM	1.2	211	243	7.4	8.4	75	Yes	1595
03/19/25	6:00 AM	1.1	219	234	7.4	8.1	67	Yes	1487
03/20/25	6:00 AM	1.1	228	253	7.4	8.1	67	Yes	1509
03/21/25	6:00 AM	1.0	261	261	7.5	7.7	56	Yes	1332
03/22/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/23/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/24/25	6:00 AM	1.0	103	103	7.9	7.7	55	Yes	3389
03/25/25	6:00 AM	1.2	103	125	7.9	7.9	61	Yes	3515
03/26/25	6:00 AM	1.1	125	142	8.9	8.0	59	Yes	2688
03/27/25	6:00 AM	1.1	126	138	10.3	8.2	58	Yes	2709
03/28/25	6:00 AM	1.0	100	100	9.8	8.2	60	Yes	3605
03/29/25	6:00 AM	1.1	103	113	9.6	8.1	59	Yes	3324
03/30/25	6:00 AM	1.0	98	98	9.1	7.6	49	Yes	3492
03/31/25	6:00AM	1.0	106	111	7.4	8.0	64	Yes	3195

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day