

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: June 2025							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.11	N/A	N/A	N/A	0.11
5	N/A	N/A	0.10	N/A	N/A	N/A	0.10
6	N/A	N/A	0.09	N/A	N/A	N/A	0.09
7	N/A	N/A	0.11	N/A	N/A	N/A	0.11
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.08	N/A	N/A	N/A	0.08
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08
11	N/A	N/A	0.12	N/A	N/A	N/A	0.12
12	N/A	N/A	0.11	N/A	N/A	N/A	0.11
13	N/A	N/A	0.10	N/A	N/A	N/A	0.10
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.08	N/A	N/A	N/A	0.08
16	N/A	N/A	0.09	N/A	N/A	N/A	0.09
17	N/A	N/A	0.08	N/A	N/A	N/A	0.08
18	N/A	N/A	0.07	N/A	N/A	N/A	0.07
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.08	N/A	N/A	N/A	0.08
21	N/A	N/A	0.07	N/A	N/A	N/A	0.07
22	N/A	N/A	0.07	N/A	N/A	N/A	0.07
23	N/A	N/A	0.12	N/A	N/A	N/A	0.12
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09
25	N/A	N/A	0.10	N/A	N/A	N/A	0.10
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08
28	N/A	N/A	0.10	N/A	N/A	N/A	0.10
29	N/A	N/A	0.09	N/A	N/A	N/A	0.09
30	N/A	N/A	0.12	N/A	N/A	N/A	0.12
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings $\leq$ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point $\geq$ 0.2 mg/l? YES	
All daily readings $\leq$ 5 NTU? YES							
Notes:				PRINTED NAME: <i>Steve Prestwood</i>			
				SIGNATURE <i>Steve Prestwood</i>		DATE 7/1/2025	
				PHONE #: (503) -723-3505		CERT #: T-08060	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: June 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
06/01/25	6:00 AM	1.2	87	107	15.6	8.0	37	Yes	4313
06/02/25	6:00 AM	1.1	79	89	16.5	7.8	32	Yes	4663
06/03/25	6:00 AM	1.1	79	85	17.0	8.1	35	Yes	4562
06/04/25	6:00 AM	1.2	82	96	17.4	7.9	32	Yes	4252
06/05/25	6:00 AM	1.2	76	88	16.0	7.6	30	Yes	4809
06/06/25	6:00 AM	1.2	71	85	16.8	7.9	33	Yes	5460
06/07/25	6:00 AM	1.1	67	73	17.3	7.5	27	Yes	5602
06/08/25	6:00 AM	1.0	67	70	18.9	7.5	24	Yes	5787
06/09/25	6:00 AM	1.0	66	66	20.2	7.5	22	Yes	5698
06/10/25	6:00 AM	1.1	62	67	19.3	7.7	26	Yes	5611
06/11/25	6:00 AM	1.1	66	75	19.9	8.3	31	Yes	5018
06/12/25	6:00 AM	1.1	63	72	18.2	7.9	30	Yes	5631
06/13/25	6:00 AM	1.5	62	94	17.9	7.8	31	Yes	5997
06/14/25	6:00 AM	1.0	64	66	16.2	7.7	31	Yes	5850
06/15/25	6:00 AM	1.2	63	76	17.6	7.5	27	Yes	5884
06/16/25	6:00 AM	1.2	64	74	18.5	7.5	25	Yes	5712
06/17/25	6:00 AM	1.2	64	76	18.6	7.5	26	Yes	5805
06/18/25	6:00 AM	1.1	60	66	19.1	7.7	26	Yes	5869
06/19/25	6:00 AM	1.1	73	84	17.9	7.9	31	Yes	4793
06/20/25	6:00 AM	1.2	62	72	18.1	8.0	32	Yes	5750
06/21/25	6:00 AM	1.2	65	80	16.3	8.1	37	Yes	5879
06/22/25	6:00 AM	1.2	62	72	15.3	8.0	37	Yes	5496
06/23/25	6:00 AM	0.9	75	66	17.3	7.8	30	Yes	4220
06/24/25	6:00 AM	1.0	75	71	18.4	7.9	29	Yes	4312
06/25/25	6:00 AM	1.0	71	71	18.8	7.8	28	Yes	4558
06/26/25	6:00 AM	1.2	67	83	17.3	8.0	33	Yes	5064
06/27/25	6:00 AM	1.3	69	92	17.3	7.9	32	Yes	5258
06/28/25	6:00 AM	1.3	68	85	17.4	7.9	32	Yes	5461
06/29/25	6:00 AM	1.2	64	78	19.2	7.9	29	Yes	5694
06/30/25	6:00 AM	1.2	65	76	20.3	7.7	25	Yes	5738

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day