

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B1 Month/Year: July 2025

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.09	N/A	N/A	N/A	0.09
3	N/A	N/A	0.08	N/A	N/A	N/A	0.08
4	N/A	N/A	0.11	N/A	N/A	N/A	0.11
5	N/A	N/A	0.08	N/A	N/A	N/A	0.08
6	N/A	N/A	0.07	N/A	N/A	N/A	0.07
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07
8	N/A	N/A	0.06	N/A	N/A	N/A	0.06
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.07	N/A	N/A	N/A	0.07
11	N/A	N/A	0.09	N/A	N/A	N/A	0.09
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.08	N/A	N/A	N/A	0.08
15	N/A	N/A	0.08	N/A	N/A	N/A	0.08
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09
18	N/A	N/A	0.09	N/A	N/A	N/A	0.09
19	N/A	N/A	0.10	N/A	N/A	N/A	0.10
20	N/A	N/A	0.10	N/A	N/A	N/A	0.10
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08
24	N/A	N/A	0.10	N/A	N/A	N/A	0.10
25	N/A	N/A	0.12	N/A	N/A	N/A	0.12
26	N/A	N/A	0.10	N/A	N/A	N/A	0.10
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09
31	N/A	N/A	0.09	N/A	N/A	N/A	0.09

Slow Sand/Membrane/DE Filtration/ Unfiltered

95% of daily turbidity readings ≤ 1 NTU? **YES**
 All daily readings ≤ 5 NTU? **YES**

Notes:

Monthly Summary

CT's met everyday?
 (see back)
YES

All CL2 residual at
 entry point ≥ 0.2 mg/l?
YES

PRINTED NAME: *Steve Prestwood*

SIGNATURE

Steve Prestwood

DATE 8/1/2025

PHONE #: (503) -723-3505

CERT #: T-08060

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: July 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
07/01/25	6:00 AM	1.2	55	64	21.1	7.7	23	Yes	6074
07/02/25	6:00 AM	1.1	80	84	21.4	7.8	23	Yes	4180
07/03/25	6:00 AM	1.1	69	76	20.6	7.7	24	Yes	5070
07/04/25	6:00 AM	1.2	67	78	20.1	7.8	26	Yes	5457
07/05/25	6:00 AM	1.1	60	65	18.1	7.9	30	Yes	5183
07/06/25	6:00 AM	1.2	63	74	20.1	7.8	26	Yes	5859
07/07/25	6:00 AM	1.1	65	72	20.8	7.7	24	Yes	5840
07/08/25	6:00 AM	1.0	58	59	21.6	7.8	23	Yes	5825
07/09/25	6:00 AM	1.1	70	74	21.8	7.8	23	Yes	4522
07/10/25	6:00 AM	1.2	64	79	21.2	7.9	25	Yes	5464
07/11/25	6:00 AM	1.2	65	80	20.4	7.8	26	Yes	5658
07/12/25	6:00 AM	1.3	65	82	21.2	7.7	24	Yes	5796
07/13/25	6:00 AM	1.2	63	72	22.3	7.8	22	Yes	6047
07/14/25	6:00 AM	1.1	56	60	23.0	7.7	20	Yes	5867
07/15/25	6:00 AM	1.2	64	76	22.5	7.7	21	Yes	5903
07/16/25	6:00 AM	1.2	61	72	22.3	7.7	21	Yes	6119
07/17/25	6:00 AM	1.2	56	66	22.9	7.7	20	Yes	6250
07/18/25	6:00 AM	1.2	67	79	21.9	8.0	24	Yes	4736
07/19/25	6:00 AM	1.2	62	76	22.0	7.8	23	Yes	5692
07/20/25	6:00 AM	1.2	64	75	22.0	7.8	23	Yes	5732
07/21/25	6:00 AM	1.1	64	72	19.9	7.8	26	Yes	5700
07/22/25	6:00 AM	1.1	60	66	21.1	7.9	25	Yes	5441
07/23/25	6:00 AM	1.1	61	64	21.8	7.9	24	Yes	5148
07/24/25	6:00 AM	1.1	59	67	22.6	7.8	22	Yes	5809
07/25/25	6:00 AM	1.1	63	66	22.1	7.8	22	Yes	6183
07/26/25	6:00 AM	1.1	60	66	21.5	7.9	24	Yes	6080
07/27/25	6:00 AM	1.1	62	71	20.1	7.8	26	Yes	5818
07/28/25	6:00 AM	1.2	62	72	21.1	7.6	23	Yes	5680
07/29/25	6:00 AM	1.0	60	62	21.6	7.7	22	Yes	5565
07/30/25	6:00 AM	1.0	69	71	22.0	7.8	22	Yes	4436
07/31/25	6:00AM	1.4	66	89	21.6	7.8	24	Yes	5213

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day