

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: August 2025							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.11	N/A	N/A	N/A	0.11
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08
5	N/A	N/A	0.11	N/A	N/A	N/A	0.11
6	N/A	N/A	0.10	N/A	N/A	N/A	0.10
7	N/A	N/A	0.11	N/A	N/A	N/A	0.11
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08
11	N/A	N/A	0.08	N/A	N/A	N/A	0.08
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.09	N/A	N/A	N/A	0.09
14	N/A	N/A	0.12	N/A	N/A	N/A	0.12
15	N/A	N/A	0.08	N/A	N/A	N/A	0.08
16	N/A	N/A	0.12	N/A	N/A	N/A	0.12
17	N/A	N/A	0.07	N/A	N/A	N/A	0.07
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.07	N/A	N/A	N/A	0.07
20	N/A	N/A	0.09	N/A	N/A	N/A	0.09
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.10	N/A	N/A	N/A	0.10
23	N/A	N/A	0.11	N/A	N/A	N/A	0.11
24	N/A	N/A	0.12	N/A	N/A	N/A	0.12
25	N/A	N/A	0.09	N/A	N/A	N/A	0.09
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.07	N/A	N/A	N/A	0.07
28	N/A	N/A	0.09	N/A	N/A	N/A	0.09
29	N/A	N/A	0.12	N/A	N/A	N/A	0.12
30	N/A	N/A	0.08	N/A	N/A	N/A	0.08
31	N/A	N/A	0.08	N/A	N/A	N/A	0.08
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings $\leq$ 1 NTU? YES				CT's met everyday? (see back)		All CL2 residual at entry point $\geq$ 0.2 mg/l?	
All daily readings $\leq$ 5 NTU? YES				YES		YES	
Notes:				PRINTED NAME: <i>Steve Prestwood</i>			
				SIGNATURE <i>Steve Prestwood</i>		DATE 9/4/2025	
				PHONE #: (503) -723-3505		CERT #: T-08060	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: August 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
08/01/25	6:00 AM	1.2	62	75	20.6	7.8	25	Yes	5734
08/02/25	6:00 AM	1.2	62	72	21.2	7.8	24	Yes	5788
08/03/25	6:00 AM	1.2	60	70	21.0	7.9	25	Yes	5702
08/04/25	6:00 AM	1.2	41	47	19.5	8.0	29	Yes	8282
08/05/25	6:00 AM	1.1	66	74	20.3	7.8	26	Yes	4954
08/06/25	6:00 AM	0.9	76	71	20.7	7.9	25	Yes	4028
08/07/25	6:00 AM	1.2	68	82	19.1	7.9	29	Yes	4983
08/08/25	6:00 AM	1.2	66	76	18.9	7.8	28	Yes	5112
08/09/25	6:00 AM	1.2	66	79	19.9	7.8	27	Yes	5232
08/10/25	6:00 AM	1.2	69	82	20.9	7.8	25	Yes	4987
08/11/25	6:00 AM	1.2	70	82	21.8	7.7	22	Yes	4738
08/12/25	6:00 AM	1.1	73	81	22.2	7.8	22	Yes	4499
08/13/25	6:00 AM	1.1	80	86	22.7	7.8	21	Yes	3923
08/14/25	6:00 AM	1.2	76	91	22.3	7.8	22	Yes	4428
08/15/25	6:00 AM	1.2	79	91	21.2	7.9	25	Yes	4089
08/16/25	6:00 AM	1.2	98	114	20.3	7.7	25	Yes	3130
08/17/25	6:00 AM	1.2	92	109	20.8	7.9	26	Yes	3470
08/18/25	6:00 AM	1.2	94	111	20.8	7.9	26	Yes	3405
08/19/25	6:00 AM	1.1	94	106	20.5	7.8	25	Yes	3266
08/20/25	6:00 AM	1.1	102	109	20.8	7.9	25	Yes	2851
08/21/25	6:00 AM	1.3	113	145	20.9	7.9	26	Yes	2553
08/22/25	6:00 AM	1.4	78	112	20.6	7.9	27	Yes	4288
08/23/25	6:00 AM	1.6	70	109	20.8	7.8	26	Yes	4457
08/24/25	6:00 AM	1.1	82	91	21.4	7.8	24	Yes	4125
08/25/25	6:00 AM	1.1	105	113	21.6	8.0	25	Yes	2868
08/26/25	6:00 AM	1.2	93	113	21.2	7.9	25	Yes	3424
08/27/25	6:00 AM	1.2	101	121	21.7	7.9	24	Yes	3124
08/28/25	6:00 AM	1.1	102	110	21.1	8.1	27	Yes	2770
08/29/25	6:00 AM	1.1	93	105	21.6	7.8	23	Yes	3450
08/30/25	6:00 AM	1.2	88	108	20.5	7.8	25	Yes	3673
08/31/25	6:00AM	1.4	96	133	19.5	7.9	28	Yes	3205

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day