

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: September 2025

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07
3	N/A	N/A	0.10	N/A	N/A	N/A	0.10
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07
5	N/A	N/A	0.08	N/A	N/A	N/A	0.08
6	N/A	N/A	0.09	N/A	N/A	N/A	0.09
7	N/A	N/A	0.08	N/A	N/A	N/A	0.08
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.08	N/A	N/A	N/A	0.08
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.08	N/A	N/A	N/A	0.08
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09
18	N/A	N/A	0.09	N/A	N/A	N/A	0.09
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.08	N/A	N/A	N/A	0.08
21	N/A	N/A	0.09	N/A	N/A	N/A	0.09
22	N/A	N/A	0.09	N/A	N/A	N/A	0.09
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.09	N/A	N/A	N/A	0.09
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07
30	N/A	N/A	0.06	N/A	N/A	N/A	0.06

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings $\leq$ 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point $\geq$ 0.2 mg/l? YES
All daily readings $\leq$ 5 NTU? YES			
Notes:		PRINTED NAME: <i>Steve Prestwood</i>	
		SIGNATURE <i>[Signature]</i>	DATE 10/1/2025
		PHONE #: (503) -723-3505	CERT #: T-08060

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: September 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
09/01/25	6:00 AM	1.5	97	145	20.1	7.9	28	Yes	3486
09/02/25	6:00 AM	1.1	96	106	20.0	7.9	27	Yes	3156
09/03/25	6:00 AM	1.2	89	108	20.4	7.9	26	Yes	3624
09/04/25	6:00 AM	1.2	88	106	20.2	7.9	27	Yes	3386
09/05/25	6:00 AM	1.2	97	113	20.2	8.0	28	Yes	3334
09/06/25	6:00 AM	1.4	70	99	19.6	7.7	26	Yes	4578
09/07/25	6:00 AM	1.3	71	89	19.1	7.7	27	Yes	4441
09/08/25	6:00 AM	1.2	76	90	19.1	7.8	28	Yes	4449
09/09/25	6:00 AM	1.2	71	87	18.9	7.9	29	Yes	4503
09/10/25	6:00 AM	1.2	71	84	19.3	7.9	28	Yes	4438
09/11/25	6:00 AM	1.2	79	95	18.5	7.9	30	Yes	3799
09/12/25	6:00 AM	1.5	65	94	17.6	7.9	32	Yes	4614
09/13/25	6:00 AM	1.4	71	99	17.7	7.9	32	Yes	4562
09/14/25	6:00 AM	1.3	70	87	18.2	7.9	31	Yes	4841
09/15/25	6:00 AM	1.2	69	84	17.3	8.0	33	Yes	4637
09/16/25	6:00 AM	1.2	69	80	17.4	7.9	32	Yes	4564
09/17/25	6:00 AM	1.2	70	86	18.2	7.9	31	Yes	4488
09/18/25	6:00 AM	1.1	75	80	18.3	7.9	30	Yes	4433
09/19/25	6:00 AM	1.2	68	80	17.9	7.9	31	Yes	5035
09/20/25	6:00 AM	1.2	70	81	17.6	7.9	31	Yes	4942
09/21/25	6:00 AM	1.2	70	86	17.6	8.0	33	Yes	4591
09/22/25	6:00 AM	1.2	72	83	17.0	8.0	34	Yes	4330
09/23/25	6:00 AM	1.1	89	100	16.8	8.0	34	Yes	3496
09/24/25	6:00 AM	1.0	82	84	17.9	8.1	33	Yes	3598
09/25/25	6:00 AM	1.2	67	80	17.3	7.9	32	Yes	4508
09/26/25	6:00 AM	1.1	69	74	16.4	7.9	33	Yes	4537
09/27/25	6:00 AM	1.1	73	83	15.6	7.9	35	Yes	4368
09/28/25	6:00 AM	1.2	70	81	15.4	7.9	35	Yes	4517
09/29/25	6:00 AM	1.2	76	88	15.6	7.9	35	Yes	4484
09/30/25	6:00 AM	1.2	87	101	14.9	7.9	36	Yes	3493

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day