

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: October 2025							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.08	N/A	N/A	N/A	0.08
3	N/A	N/A	0.07	N/A	N/A	N/A	0.07
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.07	N/A	N/A	N/A	0.07
7	N/A	N/A	0.08	N/A	N/A	N/A	0.08
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08
9	N/A	N/A	0.08	N/A	N/A	N/A	0.08
10	N/A	N/A	0.11	N/A	N/A	N/A	0.11
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07
12	N/A	N/A	0.06	N/A	N/A	N/A	0.06
13	N/A	N/A	0.06	N/A	N/A	N/A	0.06
14	N/A	N/A	0.07	N/A	N/A	N/A	0.07
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.11	N/A	N/A	N/A	0.11
17	N/A	N/A	0.08	N/A	N/A	N/A	0.08
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.08	N/A	N/A	N/A	0.08
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.08	N/A	N/A	N/A	0.08
22	N/A	N/A	0.11	N/A	N/A	N/A	0.11
23	N/A	N/A	0.07	N/A	N/A	N/A	0.07
24	N/A	N/A	0.10	N/A	N/A	N/A	0.10
25	N/A	N/A	0.07	N/A	N/A	N/A	0.07
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07
29	N/A	N/A	0.10	N/A	N/A	N/A	0.10
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07
31	N/A	N/A	0.09	N/A	N/A	N/A	0.09
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings $\leq$ 1 NTU? YES All daily readings $\leq$ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point $\geq$ 0.2 mg/l? YES	
Notes:				PRINTED NAME: <i>Steve Prescott</i>			
				SIGNATURE: <i>[Signature]</i>		DATE 11/5/2025	
				PHONE #: (503) -723-3505		CERT #: T-08060	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: October 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
10/01/25	6:00 AM	1.1	88	96	14.6	8.1	40	Yes	3483
10/02/25	6:00 AM	1.2	69	85	14.6	7.9	38	Yes	4480
10/03/25	6:00 AM	1.2	76	91	14.2	7.9	39	Yes	4416
10/04/25	6:00 AM	1.2	77	90	14.5	7.9	37	Yes	4422
10/05/25	6:00 AM	1.1	74	80	14.4	8.0	38	Yes	4607
10/06/25	6:00 AM	1.0	71	71	14.3	7.9	38	Yes	4610
10/07/25	6:00 AM	1.0	85	82	13.8	8.0	40	Yes	3818
10/08/25	6:00 AM	0.9	89	78	13.9	8.0	39	Yes	3532
10/09/25	6:00 AM	1.2	82	98	13.6	7.7	38	Yes	3983
10/10/25	6:00 AM	1.3	88	110	13.4	7.8	40	Yes	3884
10/11/25	6:00 AM	1.2	86	102	12.8	7.9	44	Yes	3755
10/12/25	6:00 AM	1.2	94	115	12.7	8.0	47	Yes	3625
10/13/25	6:00 AM	1.1	80	89	11.9	8.0	48	Yes	3992
10/14/25	6:00 AM	1.1	117	134	11.6	8.0	50	Yes	2620
10/15/25	6:00 AM	1.2	123	142	11.3	8.0	50	Yes	2566
10/16/25	6:00 AM	1.4	100	138	11.5	8.0	50	Yes	3075
10/17/25	6:00 AM	1.2	102	123	11.2	7.8	48	Yes	3086
10/18/25	6:00 AM	1.2	82	102	11.2	8.0	52	Yes	3648
10/19/25	6:00 AM	1.2	84	100	11.3	7.9	49	Yes	4125
10/20/25	6:00 AM	1.2	74	85	11.4	8.0	50	Yes	4380
10/21/25	6:00 AM	1.2	85	100	11.1	8.0	52	Yes	3747
10/22/25	6:00 AM	1.1	86	97	10.7	7.8	49	Yes	3634
10/23/25	6:00 AM	1.2	81	98	10.7	7.9	51	Yes	4444
10/24/25	6:00 AM	1.3	80	106	10.9	8.1	55	Yes	4552
10/25/25	6:00 AM	1.2	90	107	10.5	8.1	56	Yes	3910
10/26/25	6:00 AM	1.1	86	98	10.2	7.9	52	Yes	4315
10/27/25	6:00 AM	1.3	78	99	9.7	7.9	54	Yes	4193
10/28/25	6:00 AM	1.2	88	109	9.7	7.8	54	Yes	3717
10/29/25	6:00 AM	1.2	88	106	10.1	8.3	61	Yes	3625
10/30/25	6:00 AM	1.2	74	87	9.9	8.1	57	Yes	4501
10/31/25	6:00AM	1.3	90	112	9.2	7.8	55	Yes	3902

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day