

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: November 2025							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.09	N/A	N/A	N/A	0.09
3	N/A	N/A	0.07	N/A	N/A	N/A	0.07
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
9	N/A	N/A	0.13	N/A	N/A	N/A	0.13
10	N/A	N/A	0.15	N/A	N/A	N/A	0.15
11	N/A	N/A	0.12	N/A	N/A	N/A	0.12
12	N/A	N/A	0.12	N/A	N/A	N/A	0.12
13	N/A	N/A	0.10	N/A	N/A	N/A	0.10
14	N/A	N/A	0.08	N/A	N/A	N/A	0.08
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.08	N/A	N/A	N/A	0.08
17	N/A	N/A	0.08	N/A	N/A	N/A	0.08
18	N/A	N/A	0.09	N/A	N/A	N/A	0.09
19	N/A	N/A	0.09	N/A	N/A	N/A	0.09
20	N/A	N/A	0.10	N/A	N/A	N/A	0.10
21	N/A	N/A	0.06	N/A	N/A	N/A	0.06
22	N/A	N/A	0.10	N/A	N/A	N/A	0.10
23	N/A	N/A	0.08	N/A	N/A	N/A	0.08
24	N/A	N/A	0.08	N/A	N/A	N/A	0.08
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.10	N/A	N/A	N/A	0.10
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
29	N/A	N/A	0.09	N/A	N/A	N/A	0.09
30	N/A	N/A	0.10	N/A	N/A	N/A	0.10

Slow Sand/Membrane/DE Filtration/ Unfiltered 95% of daily turbidity readings $\leq$ 1 NTU? YES All daily readings $\leq$ 5 NTU? YES Notes:	Monthly Summary CT's met everyday? (see back) YES		All CL2 residual at entry point $\geq$ 0.2 mg/l? YES
	PRINTED NAME: <i>Steve Preswood</i>		
	SIGNATURE: <i>[Signature]</i>		DATE: 12/3/2025
	PHONE #: (503) -723-3505		CERT #: T-08060

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: November 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
11/01/25	6:00 AM	1.3	89	114	9.5	8.1	60	Yes	3973
11/02/25	6:00 AM	1.0	89	92	10.0	8.1	57	Yes	3575
11/03/25	6:00 AM	1.1	79	89	9.6	8.1	59	Yes	4071
11/04/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/05/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/06/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/07/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/08/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/09/25	6:00 AM	1.1	88	97	9.7	8.2	61	Yes	3735
11/10/25	6:00 AM	1.2	87	104	9.6	8.1	59	Yes	3848
11/11/25	6:00 AM	1.3	97	129	9.6	8.1	59	Yes	3537
11/12/25	6:00 AM	1.4	92	126	9.7	7.8	53	Yes	3542
11/13/25	6:00 AM	1.5	95	138	10.0	8.0	56	Yes	3458
11/14/25	6:00 AM	1.5	95	141	9.8	8.0	57	Yes	3542
11/15/25	6:00 AM	1.4	89	125	10.0	8.0	56	Yes	3297
11/16/25	6:00 AM	1.5	101	151	10.3	8.2	61	Yes	3287
11/17/25	6:00 AM	1.4	87	120	10.2	8.1	57	Yes	3681
11/18/25	6:00 AM	1.4	122	170	9.9	8.2	61	Yes	2635
11/19/25	6:00 AM	1.3	128	169	9.0	8.1	62	Yes	2567
11/20/25	6:00 AM	1.4	120	170	8.5	8.4	72	Yes	2527
11/21/25	6:00 AM	1.4	132	189	8.7	8.2	66	Yes	2487
11/22/25	6:00 AM	1.4	96	131	8.1	8.0	63	Yes	3308
11/23/25	6:00 AM	1.3	99	131	8.0	7.8	58	Yes	3209
11/24/25	6:00 AM	1.4	108	145	8.0	8.0	63	Yes	3260
11/25/25	6:00 AM	1.5	111	165	8.1	8.0	65	Yes	2942
11/26/25	6:00 AM	1.6	112	177	7.8	8.0	67	Yes	2870
11/27/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/28/25	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/29/25	6:00 AM	1.2	113	133	8.2	8.6	77	Yes	2657
11/30/25	6:00 AM	1.4	124	177	8.1	8.3	73	Yes	2549

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day