

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: December 2025							
\	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.11	N/A	N/A	N/A	0.11
2	N/A	N/A	0.14	N/A	N/A	N/A	0.14
3	N/A	N/A	0.18	N/A	N/A	N/A	0.18
4	N/A	N/A	0.15	N/A	N/A	N/A	0.15
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
8	N/A	N/A	0.11	N/A	N/A	N/A	0.11
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
13	N/A	N/A	0.28	N/A	N/A	N/A	0.28
14	N/A	N/A	0.27	N/A	N/A	N/A	0.27
15	N/A	N/A	0.27	N/A	N/A	N/A	0.27
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
26	N/A	N/A	0.24	N/A	N/A	N/A	0.24
27	N/A	N/A	0.43	N/A	N/A	N/A	0.43
28	N/A	N/A	0.45	N/A	N/A	N/A	0.45
29	N/A	N/A	0.46	N/A	N/A	N/A	0.46
30	N/A	N/A	0.46	N/A	N/A	N/A	0.46
31	N/A	N/A	0.44	N/A	N/A	N/A	0.44

Slow Sand/Membrane/DE Filtration/ Unfiltered 95% of daily turbidity readings $\leq$ 1 NTU? YES All daily readings $\leq$ 5 NTU? YES Notes:	Monthly Summary	
	CT's met everyday? (see back) YES	All CL2 residual at entry point $\geq$ 0.2 mg/l? YES
	PRINTED NAME: <i>Steve Prestwood</i>	
	SIGNATURE: <i>[Signature]</i>	DATE 10/1/2025
	PHONE #: (503) -723-3505	CERT #: T-08060

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B1 Month/Year: December 2025

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
12/01/25	6:00 AM	1.2	131	162	7.6	8.1	68	Yes	2432
12/02/25	6:00 AM	1.4	129	184	7.1	8.1	69	Yes	2376
12/03/25	6:00 AM	1.4	133	192	7.5	8.7	87	Yes	2306
12/04/25	6:00 AM	1.2	80	97	7.2	7.9	63	Yes	3545
12/05/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/06/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/07/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/08/25	6:00 AM	1.1	105	115	8.3	7.6	53	Yes	2843
12/09/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/10/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/11/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/12/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/13/25	6:00 AM	1.2	123	147	10.0	8.2	60	Yes	2536
12/14/25	6:00 AM	1.4	100	140	9.3	8.2	65	Yes	3196
12/15/25	6:00 AM	1.5	102	148	8.7	8.2	67	Yes	3220
12/16/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/17/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/18/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/19/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/20/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/21/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/22/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/23/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/24/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/25/25	6:00 AM	0.0	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
12/26/25	6:00 AM	1.1	176	189	9.4	9.4	82	Yes	1764
12/27/25	6:00 AM	1.7	124	206	8.3	8.3	74	Yes	2485
12/28/25	6:00 AM	1.4	117	165	7.3	7.9	64	Yes	2597
12/29/25	6:00 AM	1.4	126	177	6.5	8.4	81	Yes	2410
12/30/25	6:00 AM	1.4	139	196	7.2	8.3	75	Yes	2313
12/31/25	6:00AM	1.4	143	201	6.8	8.2	74	Yes	2198

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day