


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: January 2026							
\	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.35	N/A	N/A	N/A	0.35
2	N/A	N/A	0.40	N/A	N/A	N/A	0.40
3	N/A	N/A	0.40	N/A	N/A	N/A	0.40
4	N/A	N/A	0.36	N/A	N/A	N/A	0.36
5	N/A	N/A	0.55	N/A	N/A	N/A	0.55
6	N/A	N/A	0.57	N/A	N/A	N/A	0.57
7	N/A	N/A	0.00	N/A	N/A	N/A	0.00
8	N/A	N/A	0.29	N/A	N/A	N/A	0.29
9	N/A	N/A	0.51	N/A	N/A	N/A	0.51
10	N/A	N/A	0.53	N/A	N/A	N/A	0.53
11	N/A	N/A	0.65	N/A	N/A	N/A	0.65
12	N/A	N/A	0.54	N/A	N/A	N/A	0.54
13	N/A	N/A	0.48	N/A	N/A	N/A	0.48
14	N/A	N/A	0.41	N/A	N/A	N/A	0.41
15	N/A	N/A	0.44	N/A	N/A	N/A	0.44
16	N/A	N/A	0.32	N/A	N/A	N/A	0.32
17	N/A	N/A	0.27	N/A	N/A	N/A	0.27
18	N/A	N/A	0.25	N/A	N/A	N/A	0.25
19	N/A	N/A	0.24	N/A	N/A	N/A	0.24
20	N/A	N/A	0.19	N/A	N/A	N/A	0.19
21	N/A	N/A	0.30	N/A	N/A	N/A	0.30
22	N/A	N/A	0.26	N/A	N/A	N/A	0.26
23	N/A	N/A	0.21	N/A	N/A	N/A	0.21
24	N/A	N/A	0.18	N/A	N/A	N/A	0.18
25	N/A	N/A	0.18	N/A	N/A	N/A	0.18
26	N/A	N/A	0.18	N/A	N/A	N/A	0.18
27	N/A	N/A	0.15	N/A	N/A	N/A	0.15
28	N/A	N/A	0.14	N/A	N/A	N/A	0.14
29	N/A	N/A	0.14	N/A	N/A	N/A	0.14
30	N/A	N/A	0.16	N/A	N/A	N/A	0.16
31	N/A	N/A	0.16	N/A	N/A	N/A	0.16
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES				PRINTED NAME: Brent Carrar			
Notes:				SIGNATURE 		DATE 2/6/2026	
				PHONE #: (503) -723-3505		CERT # T-355512	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: January 2026

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
01/01/26	6:00 AM	1.4	133	188	5.9	8.2	79	Yes	2281
01/02/26	6:00 AM	1.4	95	137	6.3	8.5	87	Yes	3229
01/03/26	6:00 AM	1.4	108	154	6.6	8.0	71	Yes	2890
01/04/26	6:00 AM	1.2	125	150	7.2	8.1	67	Yes	2456
01/05/26	6:00 AM	1.3	121	151	8.1	8.1	65	Yes	2545
01/06/26	6:00 AM	1.3	131	163	7.8	8.1	66	Yes	2523
01/07/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/08/26	6:00 AM	0.8	252	207	7.5	8.9	84	Yes	1219
01/09/26	6:00 AM	1.2	181	219	7.1	8.5	81	Yes	1781
01/10/26	6:00 AM	1.3	170	225	6.9	8.5	81	Yes	1807
01/11/26	6:00 AM	1.3	146	182	7.1	8.3	74	Yes	2232
01/12/26	6:00 AM	1.3	104	139	7.6	8.3	72	Yes	2986
01/13/26	6:00 AM	1.4	125	171	7.2	8.0	68	Yes	2702
01/14/26	6:00 AM	1.4	125	171	7.1	8.1	71	Yes	2598
01/15/26	6:00 AM	1.4	130	178	7.4	8.1	70	Yes	2451
01/16/26	6:00 AM	1.4	142	202	6.7	8.3	78	Yes	2268
01/17/26	6:00 AM	1.5	147	218	6.2	8.4	85	Yes	2174
01/18/26	6:00 AM	1.4	159	226	6.2	8.1	76	Yes	2067
01/19/26	6:00 AM	1.4	179	247	6.1	8.4	83	Yes	1861
01/20/26	6:00 AM	1.4	117	164	5.9	8.2	77	Yes	2850
01/21/26	6:00 AM	1.3	119	159	5.9	7.7	63	Yes	2833
01/22/26	6:00 AM	1.3	117	147	6.1	7.9	68	Yes	2795
01/23/26	6:00 AM	1.3	109	144	4.5	8.0	80	Yes	2814
01/24/26	6:00 AM	1.4	117	165	4.3	8.0	82	Yes	2722
01/25/26	6:00 AM	1.4	131	183	4.3	8.0	79	Yes	2548
01/26/26	6:00 AM	1.4	123	172	5.2	7.9	73	Yes	2622
01/27/26	6:00 AM	1.4	122	170	4.3	8.0	82	Yes	2601
01/28/26	6:00 AM	1.4	129	179	4.5	8.1	82	Yes	2574
01/29/26	6:00 AM	1.4	134	190	5.1	8.1	79	Yes	2378
01/30/26	6:00 AM	1.4	124	176	5.6	8.1	77	Yes	2538
01/31/26	6:00AM	1.4	136	193	5.1	7.9	74	Yes	2446

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day