


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: February 2026							
\	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.20	N/A	N/A	N/A	0.20
2	N/A	N/A	0.23	N/A	N/A	N/A	0.23
3	N/A	N/A	0.20	N/A	N/A	N/A	0.20
4	N/A	N/A	0.17	N/A	N/A	N/A	0.17
5	N/A	N/A	0.15	N/A	N/A	N/A	0.15
6	N/A	N/A	0.14	N/A	N/A	N/A	0.14
7	N/A	N/A	0.14	N/A	N/A	N/A	0.14
8	N/A	N/A	0.12	N/A	N/A	N/A	0.12
9	N/A	N/A	N/A	N/A	N/A	N/A	Down
10	N/A	N/A	0.14	N/A	N/A	N/A	0.14
11	N/A	N/A	0.15	N/A	N/A	N/A	0.15
12	N/A	N/A	0.17	N/A	N/A	N/A	0.17
13	N/A	N/A	0.21	N/A	N/A	N/A	0.21
14	N/A	N/A	0.18	N/A	N/A	N/A	0.18
15	N/A	N/A	0.14	N/A	N/A	N/A	0.14
16	N/A	N/A	0.13	N/A	N/A	N/A	0.13
17	N/A	N/A	0.12	N/A	N/A	N/A	0.12
18	N/A	N/A	0.12	N/A	N/A	N/A	0.12
19	N/A	N/A	0.11	N/A	N/A	N/A	0.11
20	N/A	N/A	0.11	N/A	N/A	N/A	0.11
21	N/A	N/A	0.11	N/A	N/A	N/A	0.11
22	N/A	N/A	0.19	N/A	N/A	N/A	0.19
23	N/A	N/A	N/A	N/A	N/A	N/A	Down
24	N/A	N/A	N/A	N/A	N/A	N/A	Down
25	N/A	N/A	N/A	N/A	N/A	N/A	Down
26	N/A	N/A	N/A	N/A	N/A	N/A	Down
27	N/A	N/A	N/A	N/A	N/A	N/A	Down
28	N/A	N/A	0.16	N/A	N/A	N/A	0.16
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings \leq 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES	
All daily readings \leq 5 NTU? YES				PRINTED NAME: Brent Carrar SIGNATURE  DATE 3/3/2026 PHONE #: (503) 723-3505 CERT #: T-355512			
Notes:							

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: February 2026

SLOW SAND FILTERS

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
02/01/26	6:00 AM	1.4	108	154	5.9	8.1	76	Yes	3026
02/02/26	6:00 AM	1.4	110	155	6.9	8.0	68	Yes	2967
02/03/26	6:00 AM	1.4	88	125	7.1	8.1	70	Yes	4002
02/04/26	6:00 AM	1.4	88	121	7.8	8.1	67	Yes	4118
02/05/26	6:00 AM	1.4	87	118	8.1	8.0	63	Yes	4090
02/06/26	6:00 AM	1.4	88	119	7.5	8.1	69	Yes	4135
02/07/26	6:00 AM	1.4	81	110	6.9	8.1	70	Yes	4185
02/08/26	6:00 AM	1.4	91	126	7.3	8.2	71	Yes	4126
02/09/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/10/26	6:00 AM	1.2	136	163	8.2	8.3	69	Yes	2612
02/11/26	6:00 AM	1.3	134	178	7.6	8.2	71	Yes	2673
02/12/26	6:00 AM	1.4	131	177	7.5	8.4	76	Yes	2728
02/13/26	6:00 AM	1.3	129	169	7.2	8.5	79	Yes	2694
02/14/26	6:00 AM	1.3	129	162	7.3	8.4	77	Yes	2786
02/15/26	6:00 AM	1.2	122	144	7.3	8.6	83	Yes	2695
02/16/26	6:00 AM	1.3	134	175	7.5	8.2	70	Yes	2669
02/17/26	6:00 AM	1.4	123	166	7.2	8.3	75	Yes	2909
02/18/26	6:00 AM	1.4	125	171	7.2	8.3	76	Yes	2789
02/19/26	6:00 AM	1.3	132	172	7.3	8.2	72	Yes	2669
02/20/26	6:00 AM	1.2	127	156	6.9	8.3	76	Yes	2766
02/21/26	6:00 AM	1.3	129	162	6.9	8.5	81	Yes	2688
02/22/26	6:00 AM	1.2	135	163	6.8	8.2	73	Yes	2609
02/23/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/24/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/25/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/26/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/27/26	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/28/26	6:00 AM	1.1	149	170	7.8	8.4	75	Yes	2231

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day