


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B1 Month/Year: March 2026							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.23	N/A	N/A	N/A	0.23
2	N/A	N/A	0.26	N/A	N/A	N/A	0.26
3	N/A	N/A	0.15	N/A	N/A	N/A	0.15
4	N/A	N/A	0.14	N/A	N/A	N/A	0.14
5	N/A	N/A	0.14	N/A	N/A	N/A	0.14
6	N/A	N/A	0.14	N/A	N/A	N/A	0.14
7	N/A	N/A	0.14	N/A	N/A	N/A	0.14
8	N/A	N/A	0.26	N/A	N/A	N/A	0.26
9	N/A	N/A	0.19	N/A	N/A	N/A	0.19
10	N/A	N/A	0.21	N/A	N/A	N/A	0.21
11	N/A	N/A	0.16	N/A	N/A	N/A	0.16
12	N/A	N/A	N/A	N/A	N/A	N/A	Down
13	N/A	N/A	N/A	N/A	N/A	N/A	Down
14	N/A	N/A	N/A	N/A	N/A	N/A	Down
15	N/A	N/A	N/A	N/A	N/A	N/A	Down
16	N/A	N/A	N/A	N/A	N/A	N/A	Down
17	N/A	N/A	N/A	N/A	N/A	N/A	Down
18	N/A	N/A	0.20	N/A	N/A	N/A	0.20
19	N/A	N/A	0.30	N/A	N/A	N/A	0.30
20	N/A	N/A	0.27	N/A	N/A	N/A	0.27
21	N/A	N/A	0.25	N/A	N/A	N/A	0.25
22	N/A	N/A	0.23	N/A	N/A	N/A	0.23
23	N/A	N/A	0.21	N/A	N/A	N/A	0.21
24	N/A	N/A	0.20	N/A	N/A	N/A	0.20
25	N/A	N/A	0.17	N/A	N/A	N/A	0.17
26	N/A	N/A	0.15	N/A	N/A	N/A	0.15
27	N/A	N/A	0.16	N/A	N/A	N/A	0.16
28	N/A	N/A	0.15	N/A	N/A	N/A	0.15
29	N/A	N/A	0.18	N/A	N/A	N/A	0.18
30	N/A	N/A	0.11	N/A	N/A	N/A	0.11
31	N/A	N/A	0.11	N/A	N/A	N/A	0.11
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>			
95% of daily turbidity readings $\leq$ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point $\geq$ 0.2 mg/l? YES	
All daily readings $\leq$ 5 NTU? YES				PRINTED NAME: Brent Carrar			
Notes:				SIGNATURE: 		DATE	
						04/01/26	
				PHONE #: (503) 723-3505		CERT # T-355512	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B1 Month/Year: March 2026**

**SLOW SAND FILTERS**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
03/01/26	6:00 AM	1.2	161	190	7.5	8.2	70	Yes	2020
03/02/26	6:00 AM	1.0	152	150	7.8	8.1	65	Yes	2315
03/03/26	6:00 AM	1.4	144	199	8.3	8.1	66	Yes	2285
03/04/26	6:00 AM	1.4	167	234	8.5	8.2	66	Yes	2105
03/05/26	6:00 AM	1.3	169	215	8.6	8.1	62	Yes	2053
03/06/26	6:00 AM	1.3	150	194	8.5	8.1	64	Yes	2220
03/07/26	6:00 AM	1.3	112	144	8.8	8.0	61	Yes	3122
03/08/26	6:00 AM	1.4	114	154	8.7	8.3	69	Yes	3179
03/09/26	6:00 AM	1.3	103	134	8.6	8.1	63	Yes	3350
03/10/26	6:00 AM	1.3	111	139	8.5	8.0	61	Yes	3172
03/11/26	6:00 AM	1.3	112	145	8.9	8.1	61	Yes	3155
03/12/26	6:00 AM	DOWN	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
03/13/26	6:00 AM	DOWN	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
03/14/26	6:00 AM	DOWN	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
03/15/26	6:00 AM	DOWN	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
03/16/26	6:00 AM	DOWN	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
03/17/26	6:00 AM	DOWN	DOWN	DOWN	0.0	0.0	DOWN	DOWN	0
03/18/26	6:00 AM	1.1	235	252	10.1	8.9	75	Yes	1401
03/19/26	6:00 AM	1.1	123	130	9.9	7.8	51	Yes	2714
03/20/26	6:00 AM	1.3	133	170	10.1	8.6	68	Yes	2639
03/21/26	6:00 AM	1.1	117	134	10.2	8.0	56	Yes	2962
03/22/26	6:00 AM	1.3	127	162	10.2	8.5	67	Yes	2769
03/23/26	6:00 AM	1.2	93	108	10.1	8.0	55	Yes	3772
03/24/26	6:00 AM	1.2	109	132	10.5	8.3	61	Yes	3108
03/25/26	6:00 AM	1.1	111	121	9.5	8.1	60	Yes	3292
03/26/26	6:00 AM	1.1	100	112	9.6	8.1	60	Yes	3663
03/27/26	6:00 AM	1.2	91	105	10.1	8.2	59	Yes	3804
03/28/26	6:00 AM	1.2	83	96	10.3	8.2	59	Yes	4124
03/29/26	6:00 AM	1.1	82	90	11.1	8.3	57	Yes	4151
03/30/26	6:00 AM	1.1	90	97	9.6	8.3	62	Yes	3865
03/31/26	6:00AM	1.1	107	118	9.9	8.5	66	Yes	3136

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day