


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: Feb 2021								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
2	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
3	N/A	N/A	0.02	N/A	N/A	N/A	0.02	
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
9	N/A	N/A	0.02	N/A	N/A	N/A	0.02	
10	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
13	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
15	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
16	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
17	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
18	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
19	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE: 02/28/2021	
				PHONE #: (503)-723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: Feb/2021

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
02/01/21	12:20PM	1.55	48	74	7.2	7.9	33	Yes	3154
02/02/21	6:00AM	1.52	44	67	7.2	7.7	31	Yes	3431
02/03/21	6:00AM	1.60	45	72	7.8	7.7	30	Yes	3362
02/04/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/05/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/06/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/07/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/08/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/09/21	2:00PM	1.44	129	186	7.9	8.1	34	Yes	1198
02/10/21	6:00AM	1.50	53	79	8.0	7.8	30	Yes	2901
02/11/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/12/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/13/21	6:00AM	1.56	46	72	5.7	7.9	36	Yes	3251
02/14/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/15/21	1:45PM	1.42	23	33	6.9	7.7	31	Yes	6370
02/16/21	6:00AM	1.58	24	38	6.3	7.5	30	Yes	6137
02/17/21	6:00AM	1.56	24	37	6.0	7.8	34	Yes	6325
02/18/21	6:00AM	1.56	33	51	6.8	7.8	33	Yes	4520
02/19/21	6:00AM	1.58	42	67	7.1	7.8	32	Yes	3635
02/20/21	6:00AM	1.36	32	44	6.9	7.7	30	Yes	4689
02/21/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/22/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/23/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/24/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/25/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/26/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
02/27/21	10:30AM	1.36	83	113	7.6	7.9	32	Yes	1817
02/28/21	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
			DOWN	DOWN			DOWN	DOWN	
			DOWN	DOWN			DOWN	DOWN	
			DOWN	DOWN			DOWN	DOWN	

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day