


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: MARCH 2021								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
3	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
15	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
21	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
29	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
31	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joc Rogers				
				SIGNATURE 			DATE 4-1-21	
				PHONE #: (503)-723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B2 Month/Year: MARCH 2021

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
03/01/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/02/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/03/21	12:15 PM	1.35	132	178	8.6	8.2	33	Yes	1190
03/04/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/05/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/06/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/07/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/08/21	8:25 AM	1.53	57	87	7.7	8.0	33	Yes	2651
03/09/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/10/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/11/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/12/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/13/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/14/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/15/21	6:00 AM	1.46	61	89	7.6	7.9	32	Yes	2444
03/16/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/17/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/18/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/19/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/20/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/21/21	9:00 AM	1.38	106	146	8.3	7.8	29	Yes	1396
03/22/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/23/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/24/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/25/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/26/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/27/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/28/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/29/21	6:00 AM	1.33	106	141	8.7	8.1	32	Yes	1485
03/30/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN
03/31/21	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day