


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: June 2021							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.05	N/A	N/A	N/A	0.05
2	N/A	N/A	0.06	N/A	N/A	N/A	0.06
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06
4	N/A	N/A	0.07	N/A	N/A	N/A	0.07
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.04	N/A	N/A	N/A	0.04
8	N/A	N/A	0.04	N/A	N/A	N/A	0.04
9	N/A	N/A	0.04	N/A	N/A	N/A	0.04
10	N/A	N/A	0.04	N/A	N/A	N/A	0.04
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07
12	N/A	N/A	0.04	N/A	N/A	N/A	0.04
13	N/A	N/A	0.06	N/A	N/A	N/A	0.06
14	N/A	N/A	0.07	N/A	N/A	N/A	0.07
15	N/A	N/A	0.06	N/A	N/A	N/A	0.06
16	N/A	N/A	0.04	N/A	N/A	N/A	0.04
17	N/A	N/A	0.04	N/A	N/A	N/A	0.04
18	N/A	N/A	0.06	N/A	N/A	N/A	0.06
19	N/A	N/A	0.05	N/A	N/A	N/A	0.05
20	N/A	N/A	0.04	N/A	N/A	N/A	0.04
21	N/A	N/A	0.04	N/A	N/A	N/A	0.04
22	N/A	N/A	0.04	N/A	N/A	N/A	0.04
23	N/A	N/A	0.04	N/A	N/A	N/A	0.04
24	N/A	N/A	0.05	N/A	N/A	N/A	0.05
25	N/A	N/A	0.05	N/A	N/A	N/A	0.05
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.07	N/A	N/A	N/A	0.07
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07
29	N/A	N/A	0.05	N/A	N/A	N/A	0.05
30	N/A	N/A	0.05	N/A	N/A	N/A	0.05
31	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Slow Sand/Membrane/DE Filtration/ Unfiltered	<b>Monthly Summary</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <b>YES</b> All daily readings $\leq$ 5 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point $\geq$ 0.2 mg/l? <b>YES</b>
<b>Notes:</b>	<b>PRINTED NAME: Joe Rogers</b>	
	<b>SIGNATURE</b> 	<b>DATE: 6/30/2021</b>
	<b>PHONE #: (503) -723-3505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: June 2021**

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
06/01/21	6:00AM	1.27	32	41	15.1	7.5	15	Yes	4554
06/02/21	6:00AM	1.32	33	43	16.7	7.5	14	Yes	4526
06/03/21	6:00AM	1.35	31	42	17.2	7.7	15	Yes	4754
06/04/21	6:00AM	1.40	29	41	19.1	8.1	16	Yes	5057
06/05/21	6:00AM	1.22	91	111	18.1	8.9	22	Yes	1593
06/06/21	6:00AM	1.25	63	78	17.3	7.7	15	Yes	2356
06/07/21	6:00AM	1.35	24	32	16.5	8.3	20	Yes	6063
06/08/21	6:00AM	1.37	35	48	16.2	7.9	17	Yes	4210
06/09/21	6:00AM	1.35	43	58	15.3	8.2	20	Yes	3640
06/10/21	6:00AM	1.32	33	43	16.3	8.3	20	Yes	4430
06/11/21	6:00AM	1.35	94	127	15.9	8.3	20	Yes	1590
06/12/21	6:00AM	1.34	89	120	16.3	8.2	19	Yes	1631
06/13/21	6:00AM	1.36	65	88	16.6	7.9	17	Yes	2330
06/14/21	6:00AM	1.19	43	52	16.2	7.8	16	Yes	3494
06/15/21	6:00AM	1.25	51	64	15.7	8.3	20	Yes	2980
06/16/21	6:00AM	1.16	26	30	16.7	8.3	19	Yes	5822
06/17/21	6:00AM	1.09	43	47	16.7	8.2	18	Yes	3506
06/18/21	6:00AM	1.12	33	37	16.7	7.8	16	Yes	4560
06/19/21	6:00AM	1.24	31	38	16.4	8.1	18	Yes	4828
06/20/21	6:00AM	1.11	22	24	17.4	7.6	14	Yes	6758
06/21/21	6:00AM	1.13	20	23	19.3	7.5	12	Yes	7361
06/22/21	6:00AM	1.14	23	26	20.0	7.5	12	Yes	6542
06/23/21	6:00AM	1.15	28	32	19.1	7.9	14	Yes	5233
06/24/21	6:00AM	1.09	21	22	19.7	8.2	15	Yes	7169
06/25/21	6:00AM	1.13	25	29	20.3	7.7	12	Yes	5857
06/26/21	6:00AM	1.11	22	25	21.0	7.8	12	Yes	6716
06/27/21	6:00AM	1.10	27	29	22.0	8.1	12	Yes	5543
06/28/21	6:00AM	1.14	21	23	23.0	7.9	11	Yes	7174
06/29/21	6:00AM	1.14	20	23	23.6	7.9	10	Yes	7204
06/30/21	6:00AM	1.14	20	23	22.8	8.0	11	Yes	7187

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day