


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B2 Month/Year: July 2021

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.05	N/A	N/A	N/A	0.05
2	N/A	N/A	0.05	N/A	N/A	N/A	0.05
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06
4	N/A	N/A	0.05	N/A	N/A	N/A	0.05
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06
6	N/A	N/A	0.08	N/A	N/A	N/A	0.08
7	N/A	N/A	0.04	N/A	N/A	N/A	0.04
8	N/A	N/A	0.04	N/A	N/A	N/A	0.04
9	N/A	N/A	0.04	N/A	N/A	N/A	0.04
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.05	N/A	N/A	N/A	0.05
12	N/A	N/A	0.07	N/A	N/A	N/A	0.07
13	N/A	N/A	0.04	N/A	N/A	N/A	0.04
14	N/A	N/A	0.04	N/A	N/A	N/A	0.04
15	N/A	N/A	0.04	N/A	N/A	N/A	0.04
16	N/A	N/A	0.06	N/A	N/A	N/A	0.06
17	N/A	N/A	0.08	N/A	N/A	N/A	0.08
18	N/A	N/A	0.05	N/A	N/A	N/A	0.05
19	N/A	N/A	0.04	N/A	N/A	N/A	0.04
20	N/A	N/A	0.04	N/A	N/A	N/A	0.04
21	N/A	N/A	0.04	N/A	N/A	N/A	0.04
22	N/A	N/A	0.05	N/A	N/A	N/A	0.05
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05
24	N/A	N/A	0.07	N/A	N/A	N/A	0.07
25	N/A	N/A	0.04	N/A	N/A	N/A	0.04
26	N/A	N/A	0.03	N/A	N/A	N/A	0.03
27	N/A	N/A	0.03	N/A	N/A	N/A	0.03
28	N/A	N/A	0.04	N/A	N/A	N/A	0.04
29	N/A	N/A	0.03	N/A	N/A	N/A	0.03
30	N/A	N/A	0.05	N/A	N/A	N/A	0.05
31	N/A	N/A	0.04	N/A	N/A	N/A	0.04

Slow Sand/Membrane/DE Filtration/ Unfiltered	Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES	CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
Notes:	PRINTED NAME: Joe Rogers	
	SIGNATURE 	DATE: 7/31/2021
	PHONE #: (503) 23-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year:

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
07/01/21	6:00AM	1.15	21	24	20.7	8.2	14	Yes	7147
07/02/21	6:00AM	1.15	29	33	20.2	8.2	15	Yes	5095
07/03/21	6:00AM	1.12	26	29	20.9	7.5	11	Yes	5564
07/04/21	6:00AM	1.08	32	35	21.1	7.5	11	Yes	4586
07/05/21	6:00AM	1.15	20	23	21.3	8.2	14	Yes	7301
07/06/21	6:00AM	1.30	20	26	21.4	7.5	11	Yes	7456
07/07/21	6:00AM	1.20	32	39	22.5	8.3	13	Yes	4501
07/08/21	6:00AM	1.24	23	29	20.3	8.2	15	Yes	6413
07/09/21	6:00AM	1.24	23	29	20.8	7.8	12	Yes	6266
07/10/21	6:00AM	1.20	32	38	21.6	7.8	12	Yes	4609
07/11/21	6:00AM	1.16	29	34	22.2	7.5	10	Yes	4968
07/12/21	6:00AM	1.15	25	28	21.4	7.9	12	Yes	5982
07/13/21	6:00AM	1.19	23	27	21.7	7.8	12	Yes	6348
07/14/21	6:00AM	1.23	24	30	21.5	7.8	12	Yes	6051
07/15/21	6:00AM	1.19	26	30	21.1	7.8	12	Yes	5690
07/16/21	6:00AM	1.21	31	37	20.9	7.9	13	Yes	4812
07/17/21	6:00AM	1.19	30	36	21.2	8.1	13	Yes	4847
07/18/21	6:00AM	1.13	31	35	21.6	8.0	12	Yes	4783
07/19/21	6:00AM	1.23	26	32	21.7	7.9	12	Yes	5736
07/20/21	6:00AM	1.19	21	25	21.9	7.9	12	Yes	6906
07/21/21	6:00AM	1.21	21	25	21.4	8.0	13	Yes	7028
07/22/21	6:00AM	1.20	26	31	20.4	7.9	13	Yes	5576
07/23/21	6:00AM	1.32	29	38	20.8	7.9	13	Yes	5133
07/24/21	6:00AM	1.16	29	33	21.5	7.5	11	Yes	5215
07/25/21	6:00AM	1.19	29	34	22.1	7.6	11	Yes	5236
07/26/21	6:00AM	1.15	20	23	22.0	7.7	11	Yes	7235
07/27/21	6:00AM	1.15	21	24	22.7	7.8	11	Yes	7035
07/28/21	6:00AM	1.16	22	26	22.7	7.8	11	Yes	6657
07/29/21	6:00AM	1.24	28	35	22.7	7.9	11	Yes	5286
07/30/21	6:00AM	1.18	26	31	22.9	7.7	10	Yes	5667
07/31/21	6:00AM	1.17	27	31	22.1	7.6	11	Yes	5545

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day