


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: Sept 2021

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.13	N/A	N/A	N/A	0.13
3	N/A	N/A	0.07	N/A	N/A	N/A	0.07
4	N/A	N/A	0.08	N/A	N/A	N/A	0.08
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06
6	N/A	N/A	0.08	N/A	N/A	N/A	0.08
7	N/A	N/A	0.08	N/A	N/A	N/A	0.08
8	N/A	N/A	0.11	N/A	N/A	N/A	0.11
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.07	N/A	N/A	N/A	0.07
12	N/A	N/A	0.07	N/A	N/A	N/A	0.07
13	N/A	N/A	0.1	N/A	N/A	N/A	0.1
14	N/A	N/A	0.11	N/A	N/A	N/A	0.11
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.12	N/A	N/A	N/A	0.12
17	N/A	N/A	Down	N/A	N/A	N/A	Down
18	N/A	N/A	Down	N/A	N/A	N/A	Down
19	N/A	N/A	Down	N/A	N/A	N/A	Down
20	N/A	N/A	0.11	N/A	N/A	N/A	0.11
21	N/A	N/A	Down	N/A	N/A	N/A	Down
22	N/A	N/A	0.1	N/A	N/A	N/A	0.1
23	N/A	N/A	Down	N/A	N/A	N/A	Down
24	N/A	N/A	Down	N/A	N/A	N/A	Down
25	N/A	N/A	0.07	N/A	N/A	N/A	0.07
26	N/A	N/A	Down	N/A	N/A	N/A	Down
27	N/A	N/A	Down	N/A	N/A	N/A	Down
28	N/A	N/A	Down	N/A	N/A	N/A	Down
29	N/A	N/A	Down	N/A	N/A	N/A	Down
30	N/A	N/A	Down	N/A	N/A	N/A	Down
31	N/A	N/A	Down	N/A	N/A	N/A	Down

Slow Sand/Membrane/DE Filtration/ Unfiltered  
 95% of daily turbidity readings  $\leq$  1 NTU? YES  
 All daily readings  $\leq$  5 NTU? YES

Notes:

<b>Monthly Summary</b>	
CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point $\geq$ 0.2 mg/l? <b>YES</b>
PRINTED NAME: Joe Rogers	
SIGNATURE 	DATE 10/01/2021
PHONE #: (503) 733-3505	CERT #: T-09162

### OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: Sept 2021

#### Membrane Filters

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
							Use Tables	Yes / No	(gpm)
09/01/21	0600AM	1.22	26	32	17.7	7.6	14	Yes	5783
09/02/21	0600AM	1.10	35	39	18.4	7.9	15	Yes	4277
09/03/21	0600AM	1.08	34	37	17.9	7.8	15	Yes	4342
09/04/21	0600AM	1.06	31	33	17.4	7.8	15	Yes	4855
09/05/21	0600AM	1.08	27	29	18.6	7.7	14	Yes	5482
09/06/21	0600AM	1.05	35	37	19.1	7.7	13	Yes	4337
09/07/21	0600AM	1.15	24	28	18.8	7.7	14	Yes	6141
09/08/21	0600AM	1.09	27	29	18.7	8.0	15	Yes	5555
09/09/21	0600AM	1.09	27	29	18.7	8.0	15	Yes	5443
09/09/21	0600AM	1.17	28	33	19.1	8.0	15	Yes	6412
09/10/21	0600AM	1.18	24	28	18.8	7.8	14	Yes	6412
09/10/21	0600AM	1.18	24	28	18.8	7.8	16	Yes	4765
09/11/21	0600AM	1.17	31	36	16.6	7.8	16	Yes	1738
09/12/21	0600AM	1.10	88	97	18.1	8.1	16	Yes	1738
09/12/21	0600AM	1.10	88	97	18.1	8.1	15	Yes	6439
09/13/21	0600AM	1.14	23	26	16.7	7.7	15	Yes	6439
09/14/21	0600AM	1.12	25	28	17.1	8.1	17	Yes	6088
09/14/21	0600AM	1.12	25	28	17.1	8.1	17	Yes	4618
09/15/21	0600AM	1.20	32	38	18.4	8.3	17	Yes	4618
09/15/21	0600AM	1.20	32	38	18.4	8.3	19	Yes	3024
09/16/21	0600AM	1.16	49	57	17.0	8.3	19	Yes	3024
09/17/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/18/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/18/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/19/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/19/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/20/21	0600AM	1.18	51	61	15.1	7.6	16	Yes	2981
09/20/21	0600AM	1.18	51	61	15.1	7.6	16	Yes	3102
09/21/21	0600AM	1.19	48	57	15.3	7.7	16	Yes	3102
09/21/21	0600AM	1.19	48	57	15.3	7.7	16	Yes	1358
09/22/21	0600AM	1.16	113	131	16.5	7.8	16	Yes	1358
09/22/21	0600AM	1.16	113	131	16.5	7.8	16	Yes	1358
09/23/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/23/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/24/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/24/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/25/21	0600AM	1.21	61	74	16.2	8.3	20	Yes	2456
09/25/21	0600AM	1.21	61	74	16.2	8.3	20	Yes	2456
09/26/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/26/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/27/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/27/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/28/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/28/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/29/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/29/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/30/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
09/30/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day