


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

| System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B2 Month/Year: Oct 2021 |                   |                  |                  |  |                  |  |  |
|---|-------------------|------------------|------------------|--|------------------|--|--|
| Day   | 12:00 AM<br>[NTU] | 4:00 AM<br>[NTU] | 8:00 AM<br>[NTU] | Noon<br>[NTU]  | 4:00 PM<br>[NTU] | 8:00 PM<br>[NTU]   | Highest Reading of<br>the Day<br>[NTU] |
| 1   | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 2   | N/A               | N/A              | 0.07             | N/A  | N/A              | N/A  | 0.07                                   |
| 3   | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 4   | N/A               | N/A              | 0.1              | N/A  | N/A              | N/A  | 0.1                                    |
| 5   | N/A               | N/A              | 0.09             | N/A  | N/A              | N/A  | 0.09                                   |
| 6   | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 7   | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 8   | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 9   | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 10  | N/A               | N/A              | 0.06             | N/A  | N/A              | N/A  | 0.06                                   |
| 11  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 12  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 13  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 14  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 15  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 16  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 17  | N/A               | N/A              | 0.07             | N/A  | N/A              | N/A  | 0.07                                   |
| 18  | N/A               | N/A              | 0.12             | N/A  | N/A              | N/A  | 0.12                                   |
| 19  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 20  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 21  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 22  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 23  | N/A               | N/A              | 0.06             | N/A  | N/A              | N/A  | 0.06                                   |
| 24  | N/A               | N/A              | 0.06             | N/A  | N/A              | N/A  | 0.06                                   |
| 25  | N/A               | N/A              | 0.07             | N/A  | N/A              | N/A  | 0.07                                   |
| 26  | N/A               | N/A              | 0.1              | N/A  | N/A              | N/A  | 0.1                                    |
| 27  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 28  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 29  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| 30  | N/A               | N/A              | 0.06             | N/A  | N/A              | N/A  | 0.06                                   |
| 31  | N/A               | N/A              | DOWN             | N/A  | N/A              | N/A  | DOWN                                   |
| Slow Sand/Membrane/DE Filtration/ Unfiltered  |                   |                  |                  | <b>Monthly Summary</b>   |                  |  |  |
| 95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>                                     |                   |                  |                  | CT's met everyday?<br>(see back)<br><b>YES</b>   |                  | All CL2 residual at<br>entry point ≥ 0.2 mg/l?<br><b>YES</b> |  |
| All daily readings ≤ 5 NTU? <b>YES</b>  |                   |                  |                  | PRINTED NAME: Joe Rogers   |                  |  |  |
| Notes:  |                   |                  |                  | SIGNATURE  |                  | DATE 11/2/2021   |  |
|   |                   |                  |                  | PHONE #: (503) -723-3505   |                  | CERT #: T-09162  |  |

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: Oct 2021**

**Membrane Filters**

| Date     | Time   | Minimum Cl <sub>2</sub><br>Residual at 1 <sup>st</sup><br>User (C)* | Contact<br>Time<br>(T) | Actual<br>CT | Temp | pH   | Required<br>CT | CT<br>Met?* | Peak Hourly<br>Demand<br>Flow |
|----------|--------|---|------------------------|--------------|------|------|----------------|-------------|-------------------------------|
|          |        | (mg/L)  | (minutes)              | C x T        | (°C) |      | Use Tables     | Yes / No    | (gpm)                         |
| 05/01/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/02/21 | 0600AM | 1.24  | 45                     | 55           | 14.6 | 8.2  | 21             | Yes         | 3344                          |
| 05/03/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/04/21 | 0600AM | 1.62  | 50                     | 82           | 13.8 | 8.3  | 25             | Yes         | 2923                          |
| 05/05/21 | 0600AM | 1.18  | 103                    | 121          | 14.2 | 8.3  | 22             | Yes         | 1509                          |
| 05/06/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/07/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/08/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/09/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/10/21 | 0600AM | 1.23  | 100                    | 123          | 14.2 | 8.3  | 23             | Yes         | 1476                          |
| 05/11/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/12/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/13/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/14/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/15/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/16/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/17/21 | 0600AM | 1.39  | 52                     | 72           | 12.4 | 7.8  | 22             | Yes         | 2894                          |
| 05/18/21 | 0600AM | 1.35  | 99                     | 133          | 11.5 | 7.7  | 23             | Yes         | 1511                          |
| 05/19/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/20/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/21/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/22/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/23/21 | 0600AM | 1.18  | 106                    | 125          | 12.2 | 7.6  | 20             | Yes         | 1426                          |
| 05/24/21 | 0600AM | 1.11  | 90                     | 100          | 12.0 | 7.7  | 21             | Yes         | 1639                          |
| 05/25/21 | 0600AM | 1.07  | 106                    | 114          | 12.2 | 7.7  | 21             | Yes         | 1386                          |
| 05/26/21 | 0600AM | 1.04  | 51                     | 53           | 11.3 | 7.9  | 24             | Yes         | 2906                          |
| 05/27/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/28/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/29/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |
| 05/30/21 | 0600AM | 1.23  | 57                     | 71           | 11.1 | 7.6  | 22             | Yes         | 2567                          |
| 05/31/21 | 0600AM | DOWN  | DOWN                   | DOWN         | DOWN | DOWN | DOWN           | DOWN        | DOWN                          |

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day