


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: Nov 2021

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	0.09	N/A	N/A	N/A	0.09
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.06	N/A	N/A	N/A	0.06
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07
9	N/A	N/A	0.09	N/A	N/A	N/A	0.09
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08
11	N/A	N/A	0.09	N/A	N/A	N/A	0.09
12	N/A	N/A	0.09	N/A	N/A	N/A	0.09
13	N/A	N/A	0.09	N/A	N/A	N/A	0.09
14	N/A	N/A	0.09	N/A	N/A	N/A	0.09
15	N/A	N/A	0.09	N/A	N/A	N/A	0.09
16	N/A	N/A	0.09	N/A	N/A	N/A	0.09
17	N/A	N/A	0.1	N/A	N/A	N/A	0.1
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08
19	N/A	N/A	0.06	N/A	N/A	N/A	0.06
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.06	N/A	N/A	N/A	0.06
22	N/A	N/A	0.07	N/A	N/A	N/A	0.07
23	N/A	N/A	0.07	N/A	N/A	N/A	0.07
24	N/A	N/A	0.09	N/A	N/A	N/A	0.09
25	N/A	N/A	0.08	N/A	N/A	N/A	0.08
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07
29	N/A	N/A	0.06	N/A	N/A	N/A	0.06
30	N/A	N/A	0.07	N/A	N/A	N/A	0.07
31	N/A	N/A		N/A	N/A	N/A	0

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES		PRINTED NAME: Joe Rogers	
Notes:		SIGNATURE 	DATE 12/01/2021
		PHONE #: (503) -723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: Nov 2021

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
11/01/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
11/02/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
11/03/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
11/04/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
11/05/21	0600AM	1.63	35	58	10.5	8.0	28	Yes	4207
11/06/21	0600AM	1.61	40	65	9.2	7.7	27	Yes	3865
11/07/21	0600AM	1.63	57	92	8.9	7.7	28	Yes	2670
11/08/21	0600AM	1.66	32	52	8.9	7.8	29	Yes	4788
11/09/21	0600AM	1.68	35	58	8.8	7.6	27	Yes	4422
11/10/21	0600AM	1.67	34	57	8.5	7.6	28	Yes	4448
11/11/21	0600AM	1.61	52	84	8.7	7.8	29	Yes	2899
11/12/21	0600AM	1.48	32	47	10.1	7.7	25	Yes	4772
11/13/21	0600AM	1.65	32	53	10.5	7.5	23	Yes	4674
11/14/21	0600AM	1.48	55	82	10.8	7.5	22	Yes	2731
11/15/21	0600AM	1.74	32	56	11.0	7.5	23	Yes	4663
11/16/21	0600AM	1.75	34	60	10.1	8.3	33	Yes	4390
11/17/21	0600AM	1.68	33	55	9.1	7.7	28	Yes	4581
11/18/21	0600AM	1.58	33	53	9.2	8.1	32	Yes	4550
11/19/21	0600AM	1.53	43	65	9.5	8.1	31	Yes	3549
11/20/21	0600AM	1.60	35	56	8.2	8.2	35	Yes	4339
11/21/21	0600AM	1.50	34	52	7.5	7.7	30	Yes	4498
11/22/21	0600AM	1.71	33	57	7.4	7.9	34	Yes	4573
11/23/21	0600AM	1.75	37	66	7.5	8.0	35	Yes	4038
11/24/21	0600AM	1.59	36	58	8.2	8.0	33	Yes	4147
11/25/21	0600AM	1.44	40	58	7.5	8.2	36	Yes	3720
11/26/21	0600AM	1.47	54	79	8.2	7.8	30	Yes	2802
11/27/21	0600AM	1.54	49	75	8.1	8.0	33	Yes	3104
11/28/21	0600AM	1.57	34	54	8.7	8.3	35	Yes	4406
11/29/21	0600AM	1.62	35	57	8.9	7.6	27	Yes	4288
11/30/21	0600AM	1.55	34	53	9.1	7.5	25	Yes	4553
05/31/21	0600AM		DOWN	DOWN			DOWN	DOWN	

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day