


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

**System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: Dec 2021**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.08	N/A	N/A	N/A	0.08
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06
5	N/A	N/A	0.04	N/A	N/A	N/A	0.04
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	0.06	N/A	N/A	N/A	0.06
8	N/A	N/A	0.05	N/A	N/A	N/A	0.05
9	N/A	N/A	0.06	N/A	N/A	N/A	0.06
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.06	N/A	N/A	N/A	0.06
12	N/A	N/A	0.04	N/A	N/A	N/A	0.04
13	N/A	N/A	0.04	N/A	N/A	N/A	0.04
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
15	N/A	N/A	0.04	N/A	N/A	N/A	0.04
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
18	N/A	N/A	0.03	N/A	N/A	N/A	0.03
19	N/A	N/A	0.04	N/A	N/A	N/A	0.04
20	N/A	N/A	0.04	N/A	N/A	N/A	0.04
21	N/A	N/A	0.04	N/A	N/A	N/A	0.04
22	N/A	N/A	0.11	N/A	N/A	N/A	0.11
23	N/A	N/A	0.06	N/A	N/A	N/A	0.06
24	N/A	N/A	0.07	N/A	N/A	N/A	0.07
25	N/A	N/A	0.04	N/A	N/A	N/A	0.04
26	N/A	N/A	0.04	N/A	N/A	N/A	0.04
27	N/A	N/A	0.05	N/A	N/A	N/A	0.05
28	N/A	N/A	0.05	N/A	N/A	N/A	0.05
29	N/A	N/A	0.04	N/A	N/A	N/A	0.04
30	N/A	N/A	0.04	N/A	N/A	N/A	0.04
31	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN

Slow Sand/Membrane/DE Filtration/ Unfiltered	<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b> All daily readings ≤ 5 NTU? <b>YES</b>	CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
<b>Notes:</b>	<b>PRINTED NAME: Joe Rogers</b>	
	<b>SIGNATURE</b> 	<b>DATE 01/05/22</b>
	<b>PHONE #: (503) 723-3505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:- WTP-B2 Month/Year: Dec 2021**

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
12/01/21	0600AM	1.59	31	50	9.4	7.5	25	Yes	4834
12/02/21	0600AM	1.44	34	49	9.5	7.7	26	Yes	4553
12/03/21	0600AM	1.30	44	58	8.9	7.6	26	Yes	3416
12/04/21	0600AM	1.45	84	122	8.4	8.3	35	Yes	1795
12/05/21	0600AM	1.41	87	122	8.5	8.1	32	Yes	1746
12/06/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/07/21	0600AM	1.45	102	147	8.7	8.3	35	Yes	1450
12/08/21	0600AM	1.37	46	63	9.8	7.5	23	Yes	3181
12/09/21	0600AM	1.47	53	79	8.7	8.3	35	Yes	2757
12/10/21	0600AM	1.23	108	132	8.20	8.1	33	Yes	1458
12/11/21	0600AM	1.46	37	54	8.00	7.8	30	Yes	4125
12/12/21	0600AM	1.48	28	41	7.8	7.5	27	Yes	5355
12/13/21	0600AM	1.51	50	76	7.7	7.5	27	Yes	3020
12/14/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/15/21	0600AM	1.26	93	117	8.0	8.3	36	Yes	1715
12/16/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/17/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	
12/18/21	0600AM	1.36	107	145	7.5	8.3	37	Yes	1456
12/19/21	0600AM	1.47	30	44	6.8	7.5	28	Yes	4942
12/20/21	0600AM	1.58	36	57	7.4	8.1	36	Yes	4132
12/21/21	0600AM	1.48	52	78	7.0	7.8	32	Yes	2882
12/22/21	0600AM	1.66	32	53	7.2	7.9	34	Yes	4778
12/23/21	0600AM	1.46	35	51	8.2	7.5	26	Yes	4244
12/24/21	0600AM	1.45	49	72	7.2	7.7	30	Yes	3065
12/25/21	0600AM	1.44	52	75	6.8	7.5	28	Yes	2879
12/26/21	0600AM	1.40	30	43	6.2	7.5	29	Yes	4962
12/27/21	0600AM	1.62	33	54	5.5	7.8	35	Yes	4520
12/28/21	0600AM	1.57	33	52	5.0	7.5	32	Yes	4534
12/29/21	0600AM	1.71	33	57	4.8	8.1	42	Yes	4651
12/30/21	0600AM	1.38	39	54	4.8	8.2	42	Yes	3909
12/31/21	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day