


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: Feb 2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
3	N/A	N/A	0.18	N/A	N/A	N/A	0.18	
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
5	N/A	N/A	0.24	N/A	N/A	N/A	0.24	
6	N/A	N/A	0.1	N/A	N/A	N/A	0.1	
7	N/A	N/A	0.1	N/A	N/A	N/A	0.1	
8	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
9	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
10	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
11	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
12	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
16	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
18	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
19	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
25	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
31	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			2/3/2022	
				PHONE #: (503) 723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: FEB 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
01/01/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/02/22	0600AM	1.44	104	150	5.0	7.8	35	Yes	1493
01/03/22	0600AM	1.53	35	54	5.4	7.7	34	Yes	4318
01/04/22	0600AM	1.56	35	55	5.1	7.6	33	Yes	4376
01/05/22	0600AM	1.49	51	77	5.8	8.4	43	Yes	2902
01/06/22	0600AM	1.42	34	48	6.2	7.9	34	Yes	4516
01/07/22	0600AM	1.46	38	56	7.8	8.3	37	Yes	3921
01/08/22	0600AM	1.54	33	51	6.8	8.1	37	Yes	4536
01/09/22	0600AM	1.53	37	56	6.1	8.2	39	Yes	4101
01/10/22	0600AM	1.51	35	53	6.00	7.8	34	Yes	4317
01/11/22	0600AM	1.44	43	62	6.40	7.7	32	Yes	3490
01/12/22	0600AM	1.47	93	137	6.3	8.1	37	Yes	1622
01/13/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/14/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/15/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/16/22	0600AM	1.32	101	133	7.1	8.3	38	Yes	1515
01/17/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/18/22	0600AM	1.40	99	138	7.3	8.3	38	Yes	1574
01/19/22	0600AM	1.41	48	67	7.0	7.8	32	Yes	3136
01/20/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/21/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/22/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/23/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/24/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/25/22	0600AM	1.32	50	66	5.5	8.2	40	Yes	2936
01/26/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/27/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/28/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/29/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/30/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
01/31/22	0600AM	1.23	76	94	5.5	8.3	41	Yes	2003

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day