


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: FEB 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
2	N/A	N/A	0.04	N/A	N/A	N/A	0.04
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
22	N/A	N/A	0.06	N/A	N/A	N/A	0.06
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
28	N/A	N/A	0.09	N/A	N/A	N/A	0.09
29	N/A	N/A		N/A	N/A	N/A	
30	N/A	N/A		N/A	N/A	N/A	
31	N/A	N/A		N/A	N/A	N/A	

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES		PRINTED NAME: Joe Rogers	
Notes:		SIGNATURE 	DATE 3-1-22
		PHONE #: (503) -723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:-: WTP-B2 Month/Year: 2/2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
02/01/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/02/22	0600AM	1.23	76	94	5.9	8.0	36	Yes	2003
02/03/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/04/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/05/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/06/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/07/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/08/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/09/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/10/22	0600AM	1.27	102	130	7.8	8.3	36	Yes	1519
02/11/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/12/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/13/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/14/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/15/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/16/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/17/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/18/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/19/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/20/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/21/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/22/22	0600AM	1.32	72	94	6.1	8.3	40	Yes	2195
02/23/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/24/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/25/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/26/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/27/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
02/28/22	0600AM	1.63	47	76	6.1	7.7	33	Yes	3245
03/01/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/02/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/03/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day