


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: March 2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.25	N/A	N/A	N/A	0.25	
2	N/A	N/A	0.10	N/A	N/A	N/A	0.10	
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
4	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
6	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
12	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
13	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
14	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
15	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
20	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
21	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
22	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
26	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
27	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
29	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
31	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 04/01/22	
				PHONE #: (503) -723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: March 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
03/01/22	6:00 AM	1.56	34	53	6.1	7.8	34	Yes	4512
03/02/22	6:00 AM	1.45	36	52	7.1	8.0	34	Yes	4198
03/03/22	6:00 AM	1.37	35	48	7.7	7.8	30	Yes	4386
03/04/22	6:00 AM	1.42	33	47	6.9	7.9	33	Yes	4547
03/05/22	6:00 AM	1.50	36	54	6.8	8.3	39	Yes	4072
03/06/22	6:00 AM	1.41	41	58	6.8	7.9	33	Yes	3691
03/07/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/08/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/09/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/10/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/11/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/12/22	6:00 AM	1.21	106	128	6.4	7.5	29	Yes	1446
03/13/22	6:00 AM	1.32	111	147	7.8	8.2	35	Yes	1376
03/14/22	6:00 AM	1.42	63	90	7.5	8.3	37	Yes	2382
03/15/22	6:00 AM	1.28	112	144	7.7	7.7	29	Yes	1347
03/16/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/17/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/18/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/19/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/20/22	6:00 AM	1.18	115	135	8.9	8.3	33	Yes	1351
03/21/22	6:00 AM	1.24	94	116	8.4	8.3	35	Yes	1655
03/22/22	6:00 AM	1.23	112	137	8.0	7.7	28	Yes	1354
03/23/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/24/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/25/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/26/22	6:00 AM	1.40	117	164	9.1	8.1	31	Yes	1309
03/27/22	6:00 AM	1.45	102	148	9.4	7.7	26	Yes	1505
03/28/22	6:00 AM	1.30	112	146	10.0	8.6	35	Yes	1348
03/29/22	6:00 AM	1.49	73	108	9.4	7.9	29	Yes	2085
03/30/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
03/31/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day