


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: April 2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
4	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
7	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
11	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
12	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
16	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
17	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
18	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
19	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
23	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
25	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
31	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings ≤ 1 NTU? YES All daily readings ≤ 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 05/03/22	
				PHONE #: (503) -723-8505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: April 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
04/01/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/02/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/03/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/04/22	6:00 AM	1.45	116	168	9.2	8.3	34	Yes	1353
04/05/22	6:00 AM	1.41	52	73	8.5	8.0	31	Yes	2806
04/06/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/07/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/08/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/09/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/10/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/11/22	6:00 AM	1.13	113	128	10.0	8.1	29	Yes	1334
04/12/22	6:00 AM	1.16	133	155	7.2	8.1	34	Yes	1148
04/13/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/14/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/15/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/16/22	6:00 AM	1.29	114	147	7.1	8.3	38	Yes	1359
04/17/22	6:00 AM	1.39	76	106	8.1	8.3	36	Yes	2006
04/18/22	6:00 AM	1.34	110	147	10.2	8.3	31	Yes	1375
04/19/22	6:00 AM	1.30	68	88	7.8	7.7	29	Yes	2227
04/20/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/21/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/22/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/23/22	6:00 AM	1.38	85	117	8.4	8.3	35	Yes	1826
04/24/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/25/22	6:00 AM	1.27	120	152	10.7	8.5	32	Yes	1309
04/26/22	6:00 AM	1.30	57	74	9.7	8.2	31	Yes	2666
04/27/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/28/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/29/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
04/30/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/01/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day