


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B2 Month/Year: May 2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
2	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
3	N/A	N/A	0.02	N/A	N/A	N/A	0.02	
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
5	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
6	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
7	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
8	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
9	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
10	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
11	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
12	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
15	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
17	N/A	N/A	0.13	N/A	N/A	N/A	0.13	
18	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
24	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
25	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
31	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary				
95% of daily turbidity readings \leq 1 NTU? YES All daily readings \leq 5 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point \geq 0.2 mg/l? YES		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 06/01/22	
				PHONE #: (503) 723-3505			CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: May 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
05/01/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/02/22	6:00 AM	1.17	48	56	9.8	8.1	29	Yes	3246
05/03/22	6:00 AM	1.30	66	86	9.6	7.8	27	Yes	2253
05/04/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/05/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/06/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/07/22	6:00 AM	1.50	33	50	9.1	7.9	29	Yes	4541
05/08/22	6:00 AM	1.41	38	53	8.1	7.9	31	Yes	4065
05/09/22	6:00 AM	1.44	40	57	7.5	8.0	33	Yes	3769
05/10/22	6:00 AM	1.50	40	60	7.7	7.7	30	Yes	3836
05/11/22	6:00 AM	1.12	108	121	10.1	8.3	31	Yes	1419
05/12/22	6:00 AM	1.13	100	113	9.3	7.9	28	Yes	1535
05/13/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/14/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/15/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/16/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/17/22	6:00 AM	1.28	99	127	11.1	8.3	29	Yes	1546
05/18/22	6:00 AM	1.39	108	150	10.4	8.3	31	Yes	1415
05/19/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/20/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/21/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/22/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/23/22	6:00 AM	1.34	53	71	10.8	7.9	26	Yes	2786
05/24/22	6:00 AM	1.33	69	91	11.2	8.3	29	Yes	2115
05/25/22	6:00 AM	1.34	55	73	12.2	8.3	27	Yes	2730
05/26/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/27/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/28/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/29/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/30/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
05/31/22	6:00 AM	1.22	129	157	12.4	8.3	26	Yes	1219

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day