


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B2 Month/Year: June 2022							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
2	N/A	N/A	0.04	N/A	N/A	N/A	0.04
3	N/A	N/A	0.03	N/A	N/A	N/A	0.03
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	0.03	N/A	N/A	N/A	0.03
6	N/A	N/A	0.15	N/A	N/A	N/A	0.15
7	N/A	N/A	0.05	N/A	N/A	N/A	0.05
8	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
9	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.09	N/A	N/A	N/A	0.09
12	N/A	N/A	0.08	N/A	N/A	N/A	0.08
13	N/A	N/A	0.11	N/A	N/A	N/A	0.11
14	N/A	N/A	0.19	N/A	N/A	N/A	0.19
15	N/A	N/A	0.04	N/A	N/A	N/A	0.04
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
18	N/A	N/A	0.04	N/A	N/A	N/A	0.04
19	N/A	N/A	0.04	N/A	N/A	N/A	0.04
20	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
21	N/A	N/A	0.03	N/A	N/A	N/A	0.03
22	N/A	N/A	0.04	N/A	N/A	N/A	0.04
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05
24	N/A	N/A	0.04	N/A	N/A	N/A	0.04
25	N/A	N/A	0.03	N/A	N/A	N/A	0.03
26	N/A	N/A	0.03	N/A	N/A	N/A	0.03
27	N/A	N/A	0.05	N/A	N/A	N/A	0.05
28	N/A	N/A	0.04	N/A	N/A	N/A	0.04
29	N/A	N/A	0.06	N/A	N/A	N/A	0.06
30	N/A	N/A	0.05	N/A	N/A	N/A	0.05
Slow Sand/Membrane/DE Filtration/ Unfiltered				Monthly Summary			
95% of daily turbidity readings ≤ 1 NTU? YES				CT's met everyday? (see back) YES		All CL2 residual at entry point ≥ 0.2 mg/l? YES	
All daily readings ≤ 5 NTU? YES				PRINTED NAME: Joe Rogers			
Notes:				SIGNATURE 		7/1/2022	
				PHONE #: (503) -723-3505		CERT #: T-09162	

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: June 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
								Yes / No	
06/01/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/02/22	0600AM	1.30	105	136	12.8	8.3	26	Yes	1406
06/03/22	0600AM	1.30	71	93	12.8	8.3	26	Yes	2039
06/04/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/05/22	0600AM	1.28	124	159	13.1	8.3	25	Yes	1265
06/06/22	0600AM	1.42	38	54	13.7	8.3	24	Yes	3854
06/07/22	0600AM	1.31	60	78	13.1	8.3	25	Yes	2508
06/08/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/09/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/10/22	0600AM	0.96	44	42	14.1	8.2	21	Yes	3390
06/11/22	0600AM	1.22	52	64	13.1	7.7	20	Yes	2882
06/12/22	0600AM	1.35	37	50	11.5	7.7	23	Yes	4201
06/13/22	0600AM	1.31	42	56	10.6	7.8	25	Yes	3612
06/14/22	0600AM	1.28	33	43	10.4	7.9	26	Yes	4551
06/15/22	0600AM	1.40	50	70	10.2	7.8	26	Yes	3020
06/16/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/17/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/18/22	0600AM	1.25	57	72	11.9	8.0	25	Yes	2600
06/19/22	0600AM	1.41	38	54	11.2	7.8	24	Yes	3817
06/20/22	0600AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
06/21/22	0600AM	1.36	55	75	12.0	8.2	26	Yes	2668
06/22/22	0600AM	1.17	44	52	15.1	7.9	18	Yes	3423
06/23/22	0600AM	1.36	34	46	16.0	8.2	19	Yes	4439
06/24/22	0600AM	1.34	33	44	13.5	7.8	20	Yes	4445
06/25/22	0600AM	1.44	39	56	14.8	7.9	19	Yes	3893
06/26/22	0600AM	1.39	28	39	14.9	7.7	17	Yes	5133
06/27/22	0600AM	1.28	33	42	15.6	7.7	16	Yes	4471
06/28/22	0600AM	1.26	46	58	16.0	7.9	17	Yes	3301
06/29/22	0600AM	1.26	52	65	15.8	8.0	18	Yes	3002
06/30/22	0600AM	1.17	30	35	16.2	7.8	16	Yes	5064

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day