


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: July 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.07	N/A	N/A	N/A	0.07
2	N/A	N/A	0.04	N/A	N/A	N/A	0.04
3	N/A	N/A	0.05	N/A	N/A	N/A	0.05
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06
5	N/A	N/A	0.04	N/A	N/A	N/A	0.04
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07
8	N/A	N/A	0.06	N/A	N/A	N/A	0.06
9	N/A	N/A	0.05	N/A	N/A	N/A	0.05
10	N/A	N/A	0.05	N/A	N/A	N/A	0.05
11	N/A	N/A	0.06	N/A	N/A	N/A	0.06
12	N/A	N/A	0.07	N/A	N/A	N/A	0.07
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.06	N/A	N/A	N/A	0.06
15	N/A	N/A	0.06	N/A	N/A	N/A	0.06
16	N/A	N/A	0.04	N/A	N/A	N/A	0.04
17	N/A	N/A	0.04	N/A	N/A	N/A	0.04
18	N/A	N/A	0.05	N/A	N/A	N/A	0.05
19	N/A	N/A	0.05	N/A	N/A	N/A	0.05
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.06	N/A	N/A	N/A	0.06
22	N/A	N/A	0.07	N/A	N/A	N/A	0.07
23	N/A	N/A	0.06	N/A	N/A	N/A	0.06
24	N/A	N/A	0.04	N/A	N/A	N/A	0.04
25	N/A	N/A	0.05	N/A	N/A	N/A	0.05
26	N/A	N/A	0.04	N/A	N/A	N/A	0.04
27	N/A	N/A	0.05	N/A	N/A	N/A	0.05
28	N/A	N/A	0.05	N/A	N/A	N/A	0.05
29	N/A	N/A	0.04	N/A	N/A	N/A	0.04
30	N/A	N/A	0.05	N/A	N/A	N/A	0.05
31	N/A	N/A	0.05	N/A	N/A	N/A	0.05

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings \leq 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point \geq 0.2 mg/l? YES
All daily readings \leq 5 NTU? YES			
Notes:		PRINTED NAME: Joe Rogers	
		SIGNATURE 	DATE 08/01/22
		PHONE #: (503) 723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP:-: WTP-B2 Month/Year: July 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
07/01/22	6:00 AM	1.42	33	47	17.3	8.3	19	Yes	4543
07/02/22	6:00 AM	1.24	90	112	17.0	8.3	19	Yes	1682
07/03/22	6:00 AM	1.27	44	56	16.1	7.9	17	Yes	3504
07/04/22	6:00 AM	1.36	31	42	15.5	7.8	17	Yes	4975
07/05/22	6:00 AM	1.33	40	53	16.7	7.9	17	Yes	3633
07/06/22	6:00 AM	1.31	32	42	16.4	7.8	16	Yes	4670
07/07/22	6:00 AM	1.36	45	62	16.3	7.7	16	Yes	3248
07/08/22	6:00 AM	1.40	21	30	16.8	7.8	16	Yes	7070
07/09/22	6:00 AM	1.38	31	43	17.1	7.9	16	Yes	4779
07/10/22	6:00 AM	1.29	28	36	17.0	7.8	16	Yes	5288
07/11/22	6:00 AM	1.24	25	31	17.4	7.7	15	Yes	5871
07/12/22	6:00 AM	1.32	23	31	18.5	7.5	13	Yes	6370
07/13/22	6:00 AM	1.33	29	38	18.1	7.6	14	Yes	5186
07/14/22	6:00 AM	1.42	50	72	19.3	8.3	17	Yes	2997
07/15/22	6:00 AM	1.33	43	57	19.1	7.9	14	Yes	3452
07/16/22	6:00 AM	1.32	34	45	19.2	7.9	14	Yes	4316
07/17/22	6:00 AM	1.23	31	38	18.4	8.1	16	Yes	4968
07/18/22	6:00 AM	1.28	25	32	18.8	7.7	14	Yes	5809
07/19/22	6:00 AM	1.23	28	34	18.8	7.7	14	Yes	5303
07/20/22	6:00 AM	1.24	28	35	19.4	7.7	13	Yes	5198
07/21/22	6:00 AM	1.31	27	35	21.5	7.9	12	Yes	5620
07/22/22	6:00 AM	1.28	33	42	21.6	8.3	14	Yes	4489
07/23/22	6:00 AM	1.26	32	40	19.5	8.3	16	Yes	4633
07/24/22	6:00 AM	1.26	26	33	19.1	7.9	14	Yes	5633
07/25/22	6:00 AM	1.35	27	36	20.3	7.8	13	Yes	5613
07/26/22	6:00 AM	1.30	26	34	20.8	7.8	13	Yes	5738
07/27/22	6:00 AM	1.21	27	33	21.6	8.3	14	Yes	5487
07/28/22	6:00 AM	1.19	29	35	21.7	8.1	13	Yes	4955
07/29/22	6:00 AM	1.22	28	34	21.8	7.9	12	Yes	5297
07/30/22	6:00 AM	1.25	28	35	22.2	7.6	11	Yes	5338
07/31/22	6:00 AM	1.17	29	34	22.1	8.0	12	Yes	5147

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day