


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: August 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.09	N/A	N/A	N/A	0.09
2	N/A	N/A	0.09	N/A	N/A	N/A	0.09
3	N/A	N/A	0.09	N/A	N/A	N/A	0.09
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.07	N/A	N/A	N/A	0.07
7	N/A	N/A	0.06	N/A	N/A	N/A	0.06
8	N/A	N/A	0.05	N/A	N/A	N/A	0.05
9	N/A	N/A	0.06	N/A	N/A	N/A	0.06
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.05	N/A	N/A	N/A	0.05
12	N/A	N/A	0.07	N/A	N/A	N/A	0.07
13	N/A	N/A	0.06	N/A	N/A	N/A	0.06
14	N/A	N/A	0.05	N/A	N/A	N/A	0.05
15	N/A	N/A	0.05	N/A	N/A	N/A	0.05
16	N/A	N/A	0.07	N/A	N/A	N/A	0.07
17	N/A	N/A	0.07	N/A	N/A	N/A	0.07
18	N/A	N/A	0.11	N/A	N/A	N/A	0.11
19	N/A	N/A	0.05	N/A	N/A	N/A	0.05
20	N/A	N/A	0.05	N/A	N/A	N/A	0.05
21	N/A	N/A	0.04	N/A	N/A	N/A	0.04
22	N/A	N/A	0.04	N/A	N/A	N/A	0.04
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05
24	N/A	N/A	0.05	N/A	N/A	N/A	0.05
25	N/A	N/A	0.05	N/A	N/A	N/A	0.05
26	N/A	N/A	0.07	N/A	N/A	N/A	0.07
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06
28	N/A	N/A	0.06	N/A	N/A	N/A	0.06
29	N/A	N/A	0.06	N/A	N/A	N/A	0.06
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09
31	N/A	N/A	0.09	N/A	N/A	N/A	0.09

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings \leq 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point \geq 0.2 mg/l? YES
All daily readings \leq 5 NTU? YES		PRINTED NAME: Joe Rogers	
Notes:		SIGNATURE 	DATE 09/01/22
		PHONE #: (503) 723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: August 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
08/01/22	6:00 AM	1.22	25	31	22.2	8.0	12	Yes	5878
08/02/22	6:00 AM	1.21	23	28	21.5	7.8	12	Yes	6204
08/03/22	6:00 AM	1.22	25	30	21.7	7.9	12	Yes	5959
08/04/22	6:00 AM	1.28	29	38	21.7	8.0	12	Yes	4938
08/05/22	6:00 AM	1.25	34	42	20.1	8.0	14	Yes	4358
08/06/22	6:00 AM	1.16	29	33	19.9	7.8	13	Yes	5107
08/07/22	6:00 AM	1.20	32	39	20.6	7.8	13	Yes	4483
08/08/22	6:00 AM	1.25	24	30	22.0	7.6	11	Yes	6150
08/09/22	6:00 AM	1.18	31	37	21.2	8.2	14	Yes	4710
08/10/22	6:00 AM	1.16	34	40	21.5	8.3	14	Yes	4249
08/11/22	6:00 AM	1.15	25	29	19.8	8.3	16	Yes	5922
08/12/22	6:00 AM	1.24	33	41	21.5	8.3	14	Yes	4438
08/13/22	6:00 AM	1.20	28	34	20.5	8.0	14	Yes	5183
08/14/22	6:00 AM	1.24	25	31	20.9	8.1	14	Yes	5895
08/15/22	6:00 AM	1.23	24	29	20.8	7.8	12	Yes	6153
08/16/22	6:00 AM	1.25	21	26	20.9	7.8	12	Yes	6916
08/17/22	6:00 AM	1.20	25	29	20.2	7.7	13	Yes	6008
08/18/22	6:00 AM	1.14	26	30	21.1	7.7	12	Yes	5738
08/19/22	6:00 AM	1.16	21	24	20.0	7.6	12	Yes	7321
08/20/22	6:00 AM	1.15	28	33	20.8	7.8	12	Yes	5121
08/21/22	6:00 AM	1.13	26	29	19.4	7.5	12	Yes	5760
08/22/22	6:00 AM	1.13	26	29	20.9	7.8	12	Yes	5735
08/23/22	6:00 AM	1.20	24	29	20.9	7.7	12	Yes	6212
08/24/22	6:00 AM	1.21	29	35	21.2	7.6	11	Yes	5220
08/25/22	6:00 AM	1.19	32	38	21.7	7.6	11	Yes	4576
08/26/22	6:00 AM	1.18	33	38	21.7	7.6	11	Yes	4416
08/27/22	6:00 AM	1.18	31	37	20.8	7.7	12	Yes	4722
08/28/22	6:00 AM	1.15	28	33	18.8	7.6	13	Yes	5197
08/29/22	6:00 AM	1.15	32	37	20.1	7.6	12	Yes	4541
08/30/22	6:00 AM	1.18	24	29	21.0	7.6	11	Yes	5965
08/31/22	6:00 AM	1.23	24	30	21.1	7.5	11	Yes	6038

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day