


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

**System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: September 2022**

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.05	N/A	N/A	N/A	0.05
2	N/A	N/A	0.07	N/A	N/A	N/A	0.07
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06
4	N/A	N/A	0.06	N/A	N/A	N/A	0.06
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06
7	N/A	N/A	0.06	N/A	N/A	N/A	0.06
8	N/A	N/A	0.07	N/A	N/A	N/A	0.07
9	N/A	N/A	0.07	N/A	N/A	N/A	0.07
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.05	N/A	N/A	N/A	0.05
12	N/A	N/A	0.06	N/A	N/A	N/A	0.06
13	N/A	N/A	0.06	N/A	N/A	N/A	0.06
14	N/A	N/A	0.06	N/A	N/A	N/A	0.06
15	N/A	N/A	0.07	N/A	N/A	N/A	0.07
16	N/A	N/A	0.06	N/A	N/A	N/A	0.06
17	N/A	N/A	0.09	N/A	N/A	N/A	0.09
18	N/A	N/A	0.07	N/A	N/A	N/A	0.07
19	N/A	N/A	0.04	N/A	N/A	N/A	0.04
20	N/A	N/A	0.05	N/A	N/A	N/A	0.05
21	N/A	N/A	0.05	N/A	N/A	N/A	0.05
22	N/A	N/A	0.05	N/A	N/A	N/A	0.05
23	N/A	N/A	0.07	N/A	N/A	N/A	0.07
24	N/A	N/A	0.05	N/A	N/A	N/A	0.05
25	N/A	N/A	0.05	N/A	N/A	N/A	0.05
26	N/A	N/A	0.08	N/A	N/A	N/A	0.08
27	N/A	N/A	0.06	N/A	N/A	N/A	0.06
28	N/A	N/A	0.08	N/A	N/A	N/A	0.08
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN

<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>		<b>Monthly Summary</b>	
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>		CT's met everyday? (see back) <b>YES</b>	All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>
All daily readings ≤ 5 NTU? <b>YES</b>			
<b>Notes:</b>		<b>PRINTED NAME: Joe Rogers</b>	
		<b>SIGNATURE</b> 	<b>DATE 10/01/22</b>
		<b>PHONE #: (503) 723-3505</b>	<b>CERT #: T-09162</b>

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: September 2022**

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?* Yes / No	Peak Hourly Demand Flow (gpm)
09/01/22	6:00 AM	1.17	24	28	20.5	7.9	13	Yes	6042
09/02/22	6:00 AM	1.22	24	30	20.8	8.3	15	Yes	6086
09/03/22	6:00 AM	1.17	34	40	20.0	8.0	14	Yes	4282
09/04/22	6:00 AM	1.14	27	31	18.9	8.3	17	Yes	5417
09/05/22	6:00 AM	1.18	27	32	19.1	7.9	14	Yes	5464
09/06/22	6:00 AM	1.15	21	24	19.2	7.8	14	Yes	7016
09/07/22	6:00 AM	1.17	23	27	19.5	7.7	13	Yes	6298
09/08/22	6:00 AM	1.20	25	30	18.8	7.8	14	Yes	5977
09/09/22	6:00 AM	1.18	27	32	18.9	7.9	15	Yes	5392
09/10/22	6:00 AM	1.19	28	33	18.5	7.9	15	Yes	5238
09/11/22	6:00 AM	1.18	52	61	18.4	8.2	17	Yes	2905
09/12/22	6:00 AM	1.19	24	29	18.4	7.8	15	Yes	6118
09/13/22	6:00 AM	1.16	24	28	18.5	8.3	17	Yes	6202
09/14/22	6:00 AM	1.19	23	27	17.7	7.3	13	Yes	6429
09/15/22	6:00 AM	1.20	34	41	18.0	7.8	15	Yes	4459
09/16/22	6:00 AM	1.16	102	118	17.5	8.3	18	Yes	1463
09/17/22	6:00 AM	1.19	36	43	16.9	7.9	16	Yes	4228
09/18/22	6:00 AM	1.19	34	40	16.2	7.7	16	Yes	4657
09/19/22	6:00 AM	1.20	29	35	16.7	7.6	15	Yes	5086
09/20/22	6:00 AM	1.19	21	25	16.7	7.8	16	Yes	6927
09/21/22	6:00 AM	1.19	27	32	16.8	7.7	15	Yes	5702
09/22/22	6:00 AM	1.18	35	41	16.6	7.6	15	Yes	4257
09/23/22	6:00 AM	1.15	32	37	15.1	7.8	17	Yes	4550
09/24/22	6:00 AM	1.21	33	40	15.9	7.8	17	Yes	4489
09/25/22	6:00 AM	1.20	27	32	15.5	8.2	20	Yes	5630
09/26/22	6:00 AM	1.19	27	32	16.3	7.6	15	Yes	5481
09/27/22	6:00 AM	1.21	27	33	16.6	7.8	16	Yes	5371
09/28/22	6:00 AM	1.14	33	37	16.3	7.6	15	Yes	4704
09/29/22	6:00 AM	1.27	34	43	16.0	7.5	15	Yes	4432
09/30/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day