


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP:- WTP-B2 Month/Year: October 2022

Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.05	N/A	N/A	N/A	0.05
2	N/A	N/A	0.05	N/A	N/A	N/A	0.05
3	N/A	N/A	0.06	N/A	N/A	N/A	0.06
4	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
5	N/A	N/A	0.07	N/A	N/A	N/A	0.07
6	N/A	N/A	0.07	N/A	N/A	N/A	0.07
7	N/A	N/A	0.07	N/A	N/A	N/A	0.07
8	N/A	N/A	0.06	N/A	N/A	N/A	0.06
9	N/A	N/A	0.06	N/A	N/A	N/A	0.06
10	N/A	N/A	0.06	N/A	N/A	N/A	0.06
11	N/A	N/A	0.06	N/A	N/A	N/A	0.06
12	N/A	N/A	0.06	N/A	N/A	N/A	0.06
13	N/A	N/A	0.07	N/A	N/A	N/A	0.07
14	N/A	N/A	0.08	N/A	N/A	N/A	0.08
15	N/A	N/A	0.07	N/A	N/A	N/A	0.07
16	N/A	N/A	0.06	N/A	N/A	N/A	0.06
17	N/A	N/A	0.06	N/A	N/A	N/A	0.06
18	N/A	N/A	0.06	N/A	N/A	N/A	0.06
19	N/A	N/A	0.08	N/A	N/A	N/A	0.08
20	N/A	N/A	0.07	N/A	N/A	N/A	0.07
21	N/A	N/A	0.09	N/A	N/A	N/A	0.09
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
23	N/A	N/A	0.06	N/A	N/A	N/A	0.06
24	N/A	N/A	0.07	N/A	N/A	N/A	0.07
25	N/A	N/A	0.07	N/A	N/A	N/A	0.07
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
27	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
28	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
29	N/A	N/A	0.07	N/A	N/A	N/A	0.07
30	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
31	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN

Slow Sand/Membrane/DE Filtration/ Unfiltered		Monthly Summary	
95% of daily turbidity readings ≤ 1 NTU? YES		CT's met everyday? (see back) YES	All CL2 residual at entry point ≥ 0.2 mg/l? YES
All daily readings ≤ 5 NTU? YES		PRINTED NAME: Joe Rogers	
Notes:		SIGNATURE 	DATE 11/01/22
		PHONE #: (503) -723-3505	CERT #: T-09162

OHA - Drinking Water Program - Surface Water Quality Data Form

NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: October 2022

Membrane Filters

Date	Time	Minimum Cl ₂ Residual at 1 st User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
10/01/22	6:00 AM	1.21	51	62	15.8	8.0	18	Yes	2945
10/02/22	6:00 AM	1.28	31	40	16.4	8.1	18	Yes	4816
10/03/22	6:00 AM	1.25	23	29	16.4	8.0	18	Yes	6414
10/04/22	6:00 AM	1.26	97	122	15.8	7.9	18	Yes	1517
10/05/22	6:00 AM	1.33	34	45	15.2	7.7	17	Yes	4356
10/06/22	6:00 AM	1.25	102	128	15.1	8.2	20	Yes	1439
10/07/22	6:00 AM	1.26	33	41	15.3	7.9	18	Yes	4603
10/08/22	6:00 AM	1.33	93	123	15.8	7.7	16	Yes	1593
10/09/22	6:00 AM	1.41	31	43	15.1	7.7	17	Yes	4945
10/10/22	6:00 AM	1.21	45	54	15.4	7.8	17	Yes	3235
10/11/22	6:00 AM	1.27	50	63	15.4	7.7	16	Yes	2994
10/12/22	6:00 AM	1.19	52	62	15.5	8.3	20	Yes	2827
10/13/22	6:00 AM	1.17	45	53	14.9	8.1	20	Yes	3288
10/14/22	6:00 AM	1.28	32	41	15.1	8.1	20	Yes	4601
10/15/22	6:00 AM	1.33	72	96	14.7	8.3	22	Yes	2050
10/16/22	6:00 AM	1.24	49	60	14.8	8.3	21	Yes	3068
10/17/22	6:00 AM	1.20	34	41	14.2	7.8	19	Yes	4335
10/18/22	6:00 AM	1.27	31	40	14.1	8.0	21	Yes	4652
10/19/22	6:00 AM	1.27	36	46	13.8	7.8	20	Yes	4099
10/20/22	6:00 AM	1.30	49	63	14.4	8.1	21	Yes	3058
10/21/22	6:00 AM	1.16	51	60	13.5	8.3	24	Yes	2984
10/22/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
10/23/22	6:00 AM	1.34	41	55	13.0	8.3	25	Yes	3617
10/24/22	6:00 AM	1.18	105	124	12.5	8.3	26	Yes	1387
10/25/22	6:00 AM	1.23	58	71	11.8	8.3	27	Yes	2525
10/26/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
10/27/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
10/28/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
10/29/22	6:00 AM	1.07	48	51	11.4	8.0	25	Yes	2881
10/30/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
10/31/22	6:00AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0

*If Cl₂ at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day