


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: November 2022							
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]
1	N/A	N/A	0.03	N/A	N/A	N/A	0.03
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
3	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
4	N/A	N/A	0.09	N/A	N/A	N/A	0.09
5	N/A	N/A	0.05	N/A	N/A	N/A	0.05
6	N/A	N/A	0.05	N/A	N/A	N/A	0.05
7	N/A	N/A	0.09	N/A	N/A	N/A	0.09
8	N/A	N/A	0.11	N/A	N/A	N/A	0.11
9	N/A	N/A	0.04	N/A	N/A	N/A	0.04
10	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
11	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
12	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
13	N/A	N/A	0.03	N/A	N/A	N/A	0.03
14	N/A	N/A	0.02	N/A	N/A	N/A	0.02
15	N/A	N/A	0.05	N/A	N/A	N/A	0.05
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
17	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
18	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
19	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
20	N/A	N/A	0.02	N/A	N/A	N/A	0.02
21	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
22	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
23	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
24	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
25	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
26	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
27	N/A	N/A	0.05	N/A	N/A	N/A	0.05
28	N/A	N/A	0.02	N/A	N/A	N/A	0.02
29	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN
30	N/A	N/A	0.03	N/A	N/A	N/A	0.03
<b>Slow Sand/Membrane/DE Filtration/ Unfiltered</b>				<b>Monthly Summary</b>			
95% of daily turbidity readings ≤ 1 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point ≥ 0.2 mg/l? <b>YES</b>	
All daily readings ≤ 5 NTU? <b>YES</b>							
<b>Notes:</b>				<b>PRINTED NAME: Joe Rogers</b>			
				<b>SIGNATURE</b> 		<b>DATE 12/01/2022</b>	
				<b>PHONE #: (503) 723-3505</b>		<b>CERT #: T-09162</b>	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: November 2022**

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)* (mg/L)	Contact Time (T) (minutes)	Actual CT C x T	Temp (°C)	pH	Required CT Use Tables	CT Met?*	Peak Hourly Demand Flow (gpm)
11/01/22	6:00 AM	1.25	34	42	10.7	7.7	24	Yes	4444
11/02/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/03/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/04/22	6:00 AM	1.31	39	51	10.5	7.7	24	Yes	3851
11/05/22	6:00 AM	1.30	25	32	9.8	7.7	25	Yes	6032
11/06/22	6:00 AM	1.38	33	46	9.4	8.2	32	Yes	4556
11/07/22	6:00 AM	1.41	39	55	8.7	7.8	28	Yes	3886
11/08/22	6:00 AM	1.46	27	39	7.9	7.6	28	Yes	5516
11/09/22	6:00 AM	1.36	47	64	7.4	7.7	30	Yes	3242
11/10/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/11/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/12/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/13/22	6:00 AM	1.43	106	152	7.8	7.9	31	Yes	1457
11/14/22	6:00 AM	1.40	110	154	7.4	8.3	37	Yes	1410
11/15/22	6:00 AM	1.47	140	206	6.2	7.9	35	Yes	1094
11/16/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/17/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/18/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/19/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/20/22	6:00 AM	1.35	141	190	7.8	8.3	36	Yes	1090
11/21/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/22/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/23/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/24/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/25/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/26/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/27/22	6:00 AM	1.50	127	190	6.1	8.2	39	Yes	1208
11/28/22	6:00 AM	1.38	130	180	6.8	8.3	39	Yes	1177
11/29/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
11/30/22	6:00 AM	1.33	41	54	6.8	8.2	37	Yes	3697

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day