


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clackamas  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered System**

System name: NORTH CLACKAMAS COUNTY WC ID # OR4100580 WTP-: WTP-B2 Month/Year: December 2022								
Day	12:00 AM [NTU]	4:00 AM [NTU]	8:00 AM [NTU]	Noon [NTU]	4:00 PM [NTU]	8:00 PM [NTU]	Highest Reading of the Day [NTU]	
1	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
2	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
3	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
4	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
5	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
6	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
7	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
8	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
9	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
10	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
11	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
12	N/A	N/A	0.03	N/A	N/A	N/A	0.03	
13	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
14	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
15	N/A	N/A	0.06	N/A	N/A	N/A	0.06	
16	N/A	N/A	DOWN	N/A	N/A	N/A	DOWN	
17	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
18	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
19	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
20	N/A	N/A	0.04	N/A	N/A	N/A	0.04	
21	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
22	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
23	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
24	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
25	N/A	N/A	0.05	N/A	N/A	N/A	0.05	
26	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
27	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
28	N/A	N/A	0.07	N/A	N/A	N/A	0.07	
29	N/A	N/A	0.08	N/A	N/A	N/A	0.08	
30	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
31	N/A	N/A	0.09	N/A	N/A	N/A	0.09	
Slow Sand/Membrane/DE Filtration/ Unfiltered				<b>Monthly Summary</b>				
95% of daily turbidity readings $\leq$ 1 NTU? <b>YES</b> All daily readings $\leq$ 5 NTU? <b>YES</b>				CT's met everyday? (see back) <b>YES</b>		All CL2 residual at entry point $\geq$ 0.2 mg/l? <b>YES</b>		
Notes:				PRINTED NAME: Joe Rogers				
				SIGNATURE 			DATE 1/01/23	
				PHONE #: (503) -723-3505			CERT #: T-09162	

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**NORTH CLACKAMAS COUNTY WC ID#: OR4100580 WTP-: WTP-B2 Month/Year: December 2022**

**Membrane Filters**

Date	Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)*	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?*	Peak Hourly Demand Flow
		(mg/L)	(minutes)	C x T	(°C)		Use Tables	Yes / No	(gpm)
12/01/22	6:00 AM	1.53	41	62	6.4	7.8	33	Yes	3617
12/02/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/03/22	6:00 AM	1.33	57	76	6.1	8.3	40	Yes	2580
12/04/22	6:00 AM	1.56	34	53	5.5	7.7	34	Yes	4469
12/05/22	6:00 AM	1.54	35	54	5.9	7.8	34	Yes	4362
12/06/22	6:00 AM	1.49	36	54	5.3	7.7	34	Yes	4155
12/07/22	6:00 AM	1.54	34	52	5.4	7.6	32	Yes	4475
12/08/22	6:00 AM	1.53	46	70	5.6	7.8	35	Yes	3315
12/09/22	6:00 AM	1.51	37	56	5.5	7.7	33	Yes	4173
12/10/22	6:00 AM	1.46	37	54	6.7	7.7	31	Yes	4123
12/11/22	6:00 AM	1.53	52	80	6.5	7.8	33	Yes	2892
12/12/22	6:00 AM	1.39	128	178	6.8	8.3	39	Yes	1226
12/13/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/14/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/15/22	6:00 AM	1.42	54	77	5.8	8.0	37	Yes	2735
12/16/22	6:00 AM	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	DOWN	0
12/17/22	6:00 AM	1.35	105	142	4.9	8.2	41	Yes	1461
12/18/22	6:00 AM	1.42	65	93	5.5	8.3	42	Yes	2310
12/19/22	6:00 AM	1.48	110	163	5.4	8.0	38	Yes	1377
12/20/22	6:00 AM	1.48	47	69	4.9	8.0	39	Yes	3233
12/21/22	6:00 AM	1.52	55	84	5.2	8.0	38	Yes	2780
12/22/22	6:00 AM	1.52	29	45	4.0	7.6	36	Yes	5090
12/23/22	6:00 AM	1.62	71	116	2.8	7.8	44	Yes	2174
12/24/22	6:00 AM	1.37	101	139	3.8	7.8	39	Yes	1514
12/25/22	6:00 AM	1.34	47	63	3.6	7.8	40	Yes	3244
12/26/22	6:00 AM	1.45	31	45	4.9	7.7	34	Yes	4666
12/27/22	6:00 AM	1.52	30	45	7.1	7.7	31	Yes	4949
12/28/22	6:00 AM	1.53	29	45	6.9	7.6	30	Yes	5064
12/29/22	6:00 AM	1.53	35	53	7.1	7.6	30	Yes	4419
12/30/22	6:00 AM	1.40	44	62	7.1	7.6	29	Yes	3421
12/31/22	6:00AM	1.40	37	52	6.5	7.6	30	Yes	4118

\*If Cl<sub>2</sub> at entry point <0.2 mg/L OR CT not met, notify DWP by end of next business day